

Logan River Water Supply Scheme

Operational Report – Announced Allocation

Effective 1 July 2019

Parameters	Abbreviation	Value	Unit	Remarks
Announced Allocation	AA			
Date of assessment	Date	1/07/2019		
Medium Priority Users	AAMP	100.0%	%	
High Priority Users	AAHP	100.0%	%	
Useable Volume	UV			
Cedar Grove Dam	CGW	820	ML	
Bromelton off-stream storage	BOSS	-	ML	
Maroon Dam	MD	29,685	ML	
Wyaralong Dam	WD	86,552	ML	
Total useable Volume	UV	117,057	ML	
Storage Volumes at time of assessment	CV			
Cedar Grove Weir	CGW	1,144	ML	Overflowing
Bromelton off-stream storage	BOSS	-	ML	Drained / decommissioned
Maroon Dam	MD	33,267	ML	
Wyaralong Dam	WD	92,029	ML	
Total Storage Volume	CV	126,440	ML	
Minimum operating volumes				
Cedar Grove Weir	CGW	100	ML	
Bromelton off-stream storage	BOSS	1,131	ML	
Maroon Dam	MD	2,190	ML	
Wyaralong Dam	WD	264	ML	
Total	MOV	3,685	ML	
Storage Losses	SL			
Cedar Grove Weir	CGW	224	ML	
Bromelton off-stream storage	BOSS	- 1,131	ML	
Maroon Dam	MD	1,392	ML	
Wyaralong Dam	WD	5,213	ML	
Total	SL	5,698	ML	
Scheme Water Allocations	WA			
High priority allocation	HPA	9,856		
Medium Priority Allocation	MPA	13,573	ML	
Additional Parameters				
Inflow Allowance	IN	2384	ML	
Reserve Volume	RE	5000	ML	
The Volume of Water Diverted	DIV(MP+HP)	-	ML	