

Central Lockyer Valley Water Supply Scheme
Surface Water Operational Report

Parameters	Abbreviation	Value	Unit	Remarks
Announced Allocation	AA			
Date of assessment	Date	1/12/2021		
Morton Vale Pipeline	AA _{MV}	84	%	
Surface water - Zone 1	AA _{SW(z1)}	0	%	
Surface water - Zone 2	AA _{SW(z2)}	25	%	
Surface water - Zone 3	AA _{SW(z3)}	25	%	
Surface water - Zone 4	AA _{SW(z4)}	0	%	
Surface water - Zone 5	AA _{SW(z5)}	25	%	
Storage Volumes at time of assessment	CV			
Bill Gunn Dam	BDG	3408	ML	MOV = 580ML
Clarendon Dam	CLD	3090	ML	MOV = 50ML
Useable Volume	UV			
Bill Gunn Dam	BDG	2771	ML	
Clarendon Dam	CLD	3307	ML	
Surface water allocations	WA			
Morton Vale Pipeline	MPAB	3507	ML	
Surface water - Zone 1	MPAC _{z1}	1963	ML	
Surface water - Zone 2	MPAC _{z2}	2094	ML	
Surface water - Zone 3	MPAC _{z3}	1168	ML	
Surface water - Zone 4	MPAC _{z4}	6	ML	
Surface water - Zone 5	MPAC _{z5}	73	ML	
Diversions				
Morton Vale Pipeline	DIV _{MV}	0	ML	
Surface water - Zone 1	DIV _{SW(z1)}	0	ML	
Surface water - Zone 2	DIV _{SW(z1)}	0	ML	
Surface water - Zone 3	DIV _{SW(z1)}	0	ML	
Surface water - Zone 4	DIV _{SW(z1)}	0	ML	
Surface water - Zone 5	DIV _{SW(z1)}	0	ML	