

# Monthly Performance - Gold Coast

April 2026

Parameter Group	Parameter	Unit Of Measure	ADWG Criteria <sup>[37]</sup>	Number Of Samples <sup>[38]</sup>	Minimum <sup>[39]</sup>	Average <sup>[40]</sup>	Maximum <sup>[41]</sup>	Number That Passed <sup>[42]</sup>	Number That Failed <sup>[43]</sup>
Health Parameters (note That Copper And Manganese Have Both Health And Aesthetic Guideline Values)									
Chemicals	✔ Fluoride <sup>[1]</sup>	mg/L	<= 1.5	25	0.52	0.78	0.86	25	0
Chemicals	✔ Free Chlorine - Field <sup>[2]</sup>	mg/L	<= 5	25	0.9	1.6	2.1	25	0
Chemicals	✔ Total Chlorine - Field <sup>[3]</sup>	mg/L	<= 5	25	1.0	1.7	2.3	25	0
Disinfection by product	✔ Bromate <sup>[4]</sup>	mg/L	<= 0.02	5	<0.005	<0.005	<0.005	5	0
Disinfection by product	✔ Chlorate <sup>[5]</sup>	mg/L	<= 0.8	5	0.077	0.243	0.520	5	0
Metals	✔ Arsenic <sup>[6]</sup>	mg/L	<= 0.01	2	<0.0005	<0.0005	<0.0005	2	0
Metals	✔ Boron <sup>[7]</sup>	mg/L	<= 4	9	<0.03	0.16	0.67	9	0
Metals	✔ Cadmium <sup>[8]</sup>	mg/L	<= 0.002	6	<0.0001	<0.0001	<0.0001	6	0
Metals	✔ Chromium <sup>[9]</sup>	mg/L	<= 0.05	6	<0.001	<0.001	<0.001	6	0
Metals	✔ Copper <sup>[10]</sup>	mg/L	<= 2	6	<0.001	<0.001	<0.001	6	0
Metals	✔ Lead <sup>[11]</sup>	mg/L	<= 0.005	6	<0.001	<0.001	<0.001	6	0
Metals	✔ Manganese <sup>[12]</sup>	mg/L	<= 0.1	16	<0.001	0.001	0.005	16	0
Metals	✔ Nickel <sup>[13]</sup>	mg/L	<= 0.02	6	<0.001	<0.001	<0.001	6	0
Metals	✔ Selenium <sup>[14]</sup>	mg/L	<= 0.004	2	<0.002	<0.002	<0.002	2	0

Parameter Group	Parameter	Unit Of Measure	ADWG Criteria [37]	Number Of Samples [38]	Minimum [39]	Average [40]	Maximum [41]	Number That Passed [42]	Number That Failed [43]
Microbiological	✔ E.coli MF [15]	CFU/100mL	< 1	25	<1.0	<1.0	<1.0	25	0
Trihalomethanes	✔ Trihalomethanes [16]	µg/L	<= 250	6	20.0	99.0	214.0	6	0
<b>Aesthetic Parameters</b>									
Major Cations & Anions	✔ Chloride [17]	mg/L	<= 250	9	15.0	27.2	80.0	9	0
Major Cations & Anions	✔ Hardness [18]	mg/L	<= 200	9	36.0	55.2	130.0	9	0
Major Cations & Anions	✔ Sodium [19]	mg/L	<= 180	9	12.0	20.8	54.0	9	0
Major Cations & Anions	✔ Sulphate [20]	mg/L	<= 250	9	6.5	17.5	42.0	9	0
Metals	✔ Aluminium [21]	mg/L	<= 0.2	6	0.017	0.027	0.047	6	0
Metals	✔ Copper [10]	mg/L	<= 1	6	<0.001	<0.001	<0.001	6	0
Metals	✔ Iron [22]	mg/L	<= 0.3	16	<0.01	<0.01	0.01	16	0
Metals	✔ Manganese [12]	mg/L	<= 0.05	16	<0.001	0.001	0.005	16	0
Metals	✔ Zinc [23]	mg/L	<= 3	6	<0.005	0.005	0.008	6	0
Physical Properties	✔ pH - Field [24]	pH Unit	6.5 - 8.5	25	7.0	7.2	7.5	25	0
Physical Properties	✔ Total Dissolved Solids [25]	mg/L	<= 600	6	84.0	166.7	280.0	6	0
Physical Properties	✔ True Colour [26]	HU	<= 15	19	<1.0	<1.0	2.0	19	0
Physical Properties	✔ Turbidity [27]	NTU	<= 5	19	0.1	0.2	0.5	19	0
<b>Other Parameters</b>									

Parameter Group	Parameter	Unit Of Measure	ADWG Criteria <sup>[37]</sup>	Number Of Samples <sup>[38]</sup>	Minimum <sup>[39]</sup>	Average <sup>[40]</sup>	Maximum <sup>[41]</sup>	Number That Passed <sup>[42]</sup>	Number That Failed <sup>[43]</sup>
Major Cations & Anions	Calcium <sup>[28]</sup>	mg/L	N/A	9	11.0	16.4	30.0	N/A	N/A
Major Cations & Anions	Magnesium <sup>[29]</sup>	mg/L	N/A	9	0.90	3.32	13.00	N/A	N/A
Major Cations & Anions	Potassium <sup>[30]</sup>	mg/L	N/A	9	<1.0	1.1	3.0	N/A	N/A
Physical Properties	Alkalinity <sup>[31]</sup>	mg/L	N/A	2	36.0	37.0	38.0	N/A	N/A
Physical Properties	Alkalinity - Total	mg/L	N/A	0				N/A	N/A
Physical Properties	Alkalinity Total <sup>[32]</sup>	mg/L	N/A	4	40.0	53.5	79.0	N/A	N/A
Physical Properties	Conductivity <sup>[33]</sup>	µS/cm	N/A	0				N/A	N/A
Physical Properties	Conductivity - Field <sup>[34]</sup>	µS/cm	N/A	25	150.0	198.5	483.0	N/A	N/A
Physical Properties	Temperature - Field <sup>[35]</sup>	°C	N/A	25	21.1	23.6	26.0	N/A	N/A
Tastes and Odours	2-Methylisoborneol	ng/L	N/A	4	<2.0	<2.0	5.6	N/A	N/A
Tastes and Odours	Geosmin <sup>[36]</sup>	ng/L	N/A	4	<2.0	<2.0	<2.0	N/A	N/A

# Long-term performance (12 month) - Gold Coast

April 2026

Parameter Group	Parameter	Unit Of Measure	ADWG Criteria [37]	Number Of Samples [38]	Minimum [39]	Average [40]	Maximum [41]	Number That Passed [42]	Number That Failed [43]
Health Parameters (note That Copper And Manganese Have Both Health And Aesthetic Guideline Values)									
Chemicals	✔ Fluoride [1]	mg/L	<= 1.5	313	<0.05	0.76	0.89	313	0
Chemicals	✔ Fluoride IC	mg/L	<= 1.5	45	0.16	0.74	0.85	45	0
Chemicals	✔ Free Chlorine - Field [2]	mg/L	<= 5	313	0.9	1.7	2.5	313	0
Chemicals	✔ Free Chlorine External	mg/L	<= 5	45	0.76	1.24	1.70	45	0
Chemicals	✔ Total Chlorine - Field [3]	mg/L	<= 5	313	1.0	1.8	3.0	313	0
Disinfection by product	✔ Bromate [4]	mg/L	<= 0.02	64	<0.005	<0.005	0.018	64	0
Disinfection by product	✔ Chlorate [5]	mg/L	<= 0.8	72	<0.005	0.074	0.520	72	0
Disinfection by product	✔ NDMA [44]	µg/L	<= 0.1	8	<0.003	<0.003	<0.003	8	0
Haloacetic acids	✔ Chloroacetic acid [45]	µg/L	<= 150	25	<1.0	<1.0	<1.0	25	0
Haloacetic acids	✔ Dichloroacetic acid [46]	µg/L	<= 100	25	<1.0	6.8	12.0	25	0
Haloacetic acids	✔ Trichloroacetic acid [47]	µg/L	<= 100	25	<1.0	12.1	31.0	25	0
Metals	✔ Arsenic [6]	mg/L	<= 0.01	36	<0.0005	<0.0005	0.0006	36	0

Parameter Group	Parameter	Unit Of Measure	ADWG Criteria [37]	Number Of Samples [38]	Minimum [39]	Average [40]	Maximum [41]	Number That Passed [42]	Number That Failed [43]
Metals	✔ Boron [7]	mg/L	<= 4	144	<0.03	0.51	1.40	144	0
Metals	✔ Cadmium [8]	mg/L	<= 0.002	84	<0.0001	<0.0001	0.0005	84	0
Metals	✔ Chromium [9]	mg/L	<= 0.05	84	<0.001	<0.001	<0.001	84	0
Metals	✔ Copper [10]	mg/L	<= 2	118	<0.001	<0.001	0.006	118	0
Metals	✔ Lead [11]	mg/L	<= 0.005	84	<0.001	<0.001	0.001	84	0
Metals	✔ Manganese [12]	mg/L	<= 0.1	239	<0.001	0.001	0.040	239	0
Metals	✔ Mercury [48]	mg/L	<= 0.001	12	<0.0001	<0.0001	<0.0001	12	0
Metals	✔ Nickel [13]	mg/L	<= 0.02	83	<0.001	<0.001	0.001	83	0
Metals	✔ Selenium [14]	mg/L	<= 0.004	28	<0.002	<0.002	<0.002	28	0
Microbiological	✔ E.coli MF [15]	CFU/100mL	< 1	359	<1.0	<1.0	<1.0	359	0
Trihalomethanes	✔ Trihalomethanes [16]	µg/L	<= 250	83	<1.0	40.7	214.0	83	0
<b>Aesthetic Parameters</b>									
Major Cations & Anions	✔ Chloride [17]	mg/L	<= 250	147	12.0	24.1	89.0	147	0
Major Cations & Anions	✔ Hardness [18]	mg/L	<= 200	157	21.0	41.1	140.0	157	0
Major Cations & Anions	✔ Sodium [19]	mg/L	<= 180	157	10.0	18.6	56.0	157	0
Major Cations & Anions	✔ Sulphate [20]	mg/L	<= 250	112	1.7	11.4	61.0	112	0
Metals	✔ Aluminium [21]	mg/L	<= 0.2	84	<0.005	0.016	0.120	84	0

Parameter Group	Parameter	Unit Of Measure	ADWG Criteria <sup>[37]</sup>	Number Of Samples <sup>[38]</sup>	Minimum <sup>[39]</sup>	Average <sup>[40]</sup>	Maximum <sup>[41]</sup>	Number That Passed <sup>[42]</sup>	Number That Failed <sup>[43]</sup>
Metals	✔ Copper <sup>[10]</sup>	mg/L	<= 1	118	<0.001	<0.001	0.006	118	0
Metals	✔ Iron <sup>[22]</sup>	mg/L	<= 0.3	238	<0.01	<0.01	0.05	238	0
Metals	✔ Manganese <sup>[12]</sup>	mg/L	<= 0.05	239	<0.001	0.001	0.040	239	0
Metals	✔ Zinc <sup>[23]</sup>	mg/L	<= 3	84	<0.005	<0.005	0.019	84	0
Physical Properties	✔ pH - Field <sup>[24]</sup>	pH Unit	6.5 - 8.5	313	6.6	7.2	7.7	313	0
Physical Properties	✔ Total Dissolved Solids <sup>[25]</sup>	mg/L	<= 600	72	58.0	120.1	380.0	72	0
Physical Properties	✔ Total Dissolved Solids calc	mg/L	<= 600	45	58	58	160	45	0
Physical Properties	✔ True Colour <sup>[26]</sup>	HU	<= 15	278	<1.0	<1.0	13.0	278	0
Physical Properties	✘ Turbidity <sup>[27]</sup>	NTU	<= 5	278	<0.1	0.2	5.2	277	1
<b>Other Parameters</b>									
Major Cations & Anions	Calcium <sup>[28]</sup>	mg/L	N/A	157	10.0	14.7	30.0	N/A	N/A
Major Cations & Anions	Magnesium <sup>[29]</sup>	mg/L	N/A	157	<0.05	1.20	17.00	N/A	N/A
Major Cations & Anions	Potassium <sup>[30]</sup>	mg/L	N/A	157	<1.0	<1.0	3.0	N/A	N/A
Physical Properties	Alkalinity <sup>[31]</sup>	mg/L	N/A	24	27.0	38.5	52.0	N/A	N/A
Physical Properties	Alkalinity - Total	mg/L	N/A	45	40.0	50.8	70.0	N/A	N/A
Physical Properties	Alkalinity Total <sup>[32]</sup>	mg/L	N/A	48	31.0	46.6	87.0	N/A	N/A

Parameter Group	Parameter	Unit Of Measure	ADWG Criteria [37]	Number Of Samples [38]	Minimum [39]	Average [40]	Maximum [41]	Number That Passed [42]	Number That Failed [43]
Physical Properties	Conductivity [33]	µS/cm	N/A	45	160.0	200.2	270.0	N/A	N/A
Physical Properties	Conductivity - Field [34]	µS/cm	N/A	313	16.0	188.1	598.0	N/A	N/A
Physical Properties	Temperature - Field [35]	°C	N/A	313	15.3	22.0	28.5	N/A	N/A
Tastes and Odours	2-Methylisoborneol	ng/L	N/A	48	<2.0	<2.0	5.6	N/A	N/A
Tastes and Odours	Geosmin [36]	ng/L	N/A	48	<2.0	<2.0	18.9	N/A	N/A

## Descriptions

1. Low levels of fluoride occur naturally in many water sources. Fluoride is also added to drinking water in many parts of the world, including South East Queensland, to help reduce tooth decay. Not all water sources in South East Queensland are presently fluoridated. The Bulk Drinking Water Quality Report (previously called Customer Confidence Report) only covers compliance with the health standards set in the Australian Drinking Water Guidelines and the Public Health Regulation 2005. The health guideline value for fluoride is 1.5 mg/L.  
[More info](#)
2. Chlorine is the most common chemical used for the disinfection of drinking water. It is highly effective at killing bacteria and viruses, at oxidising soluble iron, manganese and sulfides, and removing tastes and odours and some algae toxins. Based on health considerations, the ADWG guideline for Total Chlorine in drinking water is 5 mg/L.  
[More info](#)
3. Chlorine is the most common chemical used for the disinfection of drinking water. It is highly effective at killing bacteria and viruses, at oxidising soluble iron, manganese and sulfides, and removing tastes and odours and some algae toxins. Based on health considerations, the ADWG guideline for Total Chlorine in drinking water is 5 mg/L.  
[More info](#)
4. Bromate is not a normal component of water, but it may be formed from bromide during ozonation within the water treatment process. Bromate has an ADWG health guideline of 0.02 mg/L.  
[More info](#)
5. Chlorates are used as herbicides and in manufacturing dyes, matches and explosives. It is also a by-product in the water treatment process. The ADWG currently doesn't have a guideline value set for chlorate due to insufficient data.  
[More info](#)
6. Arsenic is naturally occurring in the environment but can also be added through human sources, such as mining, industry and agriculture. Inorganic arsenic is highly toxic to humans and has an ADWG derived health guideline of 0.01 mg/L as set in the ADWG.  
[More info](#)
7. Boron is a metal that can occur in water through the natural leaching of boron-containing minerals or contamination. Based on health considerations, boron has an ADWG health derived guideline of 4 mg/L, however, limited information indicates that concentrations in water is less than 0.1 mg/L.  
[More info](#)
8. Cadmium is a metal that is resistant to corrosion, which is why it was often used in steel plating. It is also a common component in zinc ores and a byproduct of zinc production. Based on ADWG health guidelines, cadmium levels in water should not exceed 0.002 mg/L.  
[More info](#)
9. Chromium is present in the environment in the trivalent (CR(III)) and hexavalent (CR(VI)) states. Seqwater tests for total chromium and if total chromium exceeds the ADWG health guideline of 0.05 mg/L then additional analysis for hexavalent and trivalent chromium shall be performed.  
[More info](#)
10. Copper is a mineral widely distributed in rocks and soil and is used in domestic plumbing because it is relatively resistant to corrosion. It is present in uncontaminated surface waters at very low concentrations. Copper has both an aesthetic and a health guideline value. The aesthetic guideline value is 1 mg/L. The health guideline value is 2 mg/L.  
[More info](#)
11. Lead can be present in drinking water as a result of dissolution from natural sources or from household plumbing systems containing lead. It is not normally present in the water supplied from a water treatment plant, but may dissolve into the water supply if lead piping or joins are present in plumbing. The health guideline value for lead is 0.005 mg/L.  
[More info](#)
12. Manganese is a mineral present in the environment which can enter the water supply in its soluble form. Manganese has both an aesthetic and a health guideline value. The aesthetic guideline value is 0.05 mg/L. The health guideline value is 0.1 mg/L.  
[More info](#)
13. Nickel is a metal used largely in the electroplating industry and for making alloys. Its main releases to the environment are from burning fossil fuels and industrial waste discharges. Based on ADWG health considerations, nickel concentrations in drinking water should not exceed 0.02 mg/L.  
[More info](#)
14. Selenium and selenium salts are widespread in the environment and is naturally found in soil; however, concentrations can vary considerably between areas with higher levels found in places with recent volcanic activity. Based on ADWG health considerations, Selenium levels in water should not exceed 0.004 mg/L.  
[More info](#)
15. Escherichia coli (E. coli) is a type of bacteria used as an indicator of microbiological water quality. The health guideline value for E. coli is that none should be detected in a minimum 100 mL sample.  
[More info](#)
16. Trihalomethanes are a by-product of the chlorination and chloramination disinfection processes. Disinfection is essential to destroy microorganisms that could otherwise be harmful. The health guide value for total trihalomethanes is 0.25 mg/L.  
[More info](#)
17. Chloride is widely distributed in nature as salt through the leaching of rocks into soil and water and also through human sources such as fertilizers, effluent and landfills. Chloride does not have an ADWG

health guideline, however based on ADWG aesthetic considerations chloride concentrations exceeding 250 mg/L may be detectable to taste.

[More info](#)

18. 'Hard' water is caused by dissolved calcium and magnesium salts, particularly carbonates and bicarbonates. Total hardness is a calculation of total magnesium and calcium, whereas soluble hardness is a calculation of soluble magnesium and calcium. The aesthetic guideline value for total hardness, reported as calcium carbonate, is 200 mg/L.  
[More info](#)
19. Sodium is an essential element for all animals and many plants. It is naturally occurring in water systems, but can be added through runoff or during the water treatment process. Based on aesthetic considerations, the ADWG has specified that concentrations of sodium above 180 mg/L may affect the taste of drinking water.  
[More info](#)
20. Sulphate occurs naturally in many minerals and it is used to manufacture many products such as chemicals, paper, soaps and insecticides. Sulphate has an ADWG aesthetic guideline of 250 mg/L due to having a taste threshold between 250-500 mg/L.  
[More info](#)
21. Aluminium may be naturally present in water or from the water treatment process. Aluminium sulphate is also used extensively as a coagulant in order to treat water. The aesthetic ADWG limit for Aluminium (of  $\leq 0.2$  mg/L) refers to acid soluble Aluminium, which is a portion of total Aluminium. Total Aluminium (as reported here) is a conservative measure and will always be higher, or equal to, acid soluble aluminium.  
[More info](#)
22. Iron can occur naturally in water sources and may also enter the water supply from the corrosion of iron water pipes. The aesthetic guideline value for iron is 0.3 mg/L.  
[More info](#)
23. Zinc is a widely distributed metal and occurs in small amounts in most rocks. It is used as a coating for iron and steel products and to manufacture brass. Zinc has an ADWG aesthetic guideline of 3 mg/L as levels above this may cause taste issues.  
[More info](#)
24. pH is a measure of how acidic or alkaline the water is in the system. pH is affected by the source water and also the water treatment process. The aesthetic guideline value for drinking water is between pH 6.5 to pH 8.5. Water that is naturally pH low may need to be conditioned in order to ensure it complies with the guidelines. This is most commonly achieved by adding lime or passing the water through a bed of limestone chippings.  
[More info](#)
25. Total dissolved solids are inorganic salts and small amounts of organic matter that are dissolved in water. The aesthetic guideline value for total dissolved solids in drinking water is 600 mg/L.  
[More info](#)
26. 'True colour' is the colour of the water after particles have been removed by filtration. It is a measure of whether the water appears coloured or tinted due to parameters dissolved in the water. The aesthetic guideline value for colour is 15 Hazen Units (HU).  
[More info](#)
27. Turbidity is caused by the presence of fine suspended matter such as silt, clay, plankton, and other organisms in the water. It is a measure of the extent to which water appears cloudy or hazy. The aesthetic guideline value for turbidity is 5 Nephelometric Turbidity Units (NTU). At this level turbidity is just noticeable to the average person.  
[More info](#)
28. Calcium is an essential element for humans and it occurs naturally in water through leaching of sedimentary rocks and soil runoff. Excessive levels of calcium and magnesium can increase water hardness, leading to difficulty in soap lathering and the deposition of scale. There are no ADWG guidelines for calcium.  
[More info](#)
29. Magnesium is an essential element for humans and it occurs naturally in water through leaching of sedimentary rocks and soil runoff. Excessive levels of magnesium and calcium can increase water hardness, leading to difficulty in soap lathering and the deposition of scale. There are no ADWG guidelines for magnesium.  
[More info](#)
30. Potassium is an essential element for humans. It occurs naturally in water and can also be added during the water treatment process with the addition of potassium permanganate. There are no ADWG guidelines for potassium.  
[More info](#)
31. Alkalinity is a total measure of the parameters (carbonate, bicarbonate and hydroxide content) in water that have acid-neutralising ability. There is no guideline value for alkalinity so there will be no failure of this sample result.  
[More info](#)
32. Alkalinity is a total measure of the parameters (carbonate, bicarbonate and hydroxide content) in water that have acid-neutralising ability. There is no guideline value set for alkalinity.  
[More info](#)
33. Conductivity is the measurement of the water's ability to conduct electricity. There are no ADWG guidelines for conductivity.  
[More info](#)
34. Conductivity is the measurement of the water's ability to conduct electricity. Water is able to conduct electricity when ions are present through the dissolving of salts and other inorganic chemicals. There are no ADWG guidelines for conductivity.

- [More info](#)
35. Temperature is mainly an aesthetic criterion for drinking water, with most consumers preferring cool water. Accurate measurement of water temperature is important in the calculation of pH, conductivity and dissolved oxygen. There are no ADWG guidelines for temperature as it is impractical to try controlling the temperature of water.
- [More info](#)
36. Certain bacteria and algae species can produce taste and odour compounds which can give water a strong musty or earthy taste or smell. Geosmin has no ADWG health or aesthetic guidelines as most individuals do not find these compounds to be offensive in drinking water.
- [More info](#)
37. Health and aesthetic parameter guidelines for drinking water, as defined in the Australian Drinking Water Guidelines.
- [More info](#)
38. The number of samples tested within the reporting period.
39. The lowest result from all the samples tested within the reporting period.
40. The average of all the results within the reporting period.
41. The highest result from all the samples tested within the reporting period.
42. The number of samples that passed ADWG criteria.
43. The number of samples that failed ADWG criteria.
44. NDMA or N-Nitrosodimethylamine, is used as an industrial solvent, an anti-oxidant, rubber accelerator and in the preparation of polymers. Based on ADWG health guidelines, NDMA should not exceed 0.0001 mg/L.
- [More info](#)
45. Chloroacetic acids are produced in drinking water as a by-product of the reaction between chlorine and naturally occurring humic and fulvic acids. Based on ADWG health guidelines, the concentration of Chloroacetic acid in drinking water should not exceed 0.15 mg/L.
- [More info](#)
46. Dichloroacetic acids are produced in drinking water as a by-product of the reaction between chlorine and naturally occurring humic and fulvic acids. Based on ADWG health guidelines, the concentration of Dichloroacetic acid in drinking water should not exceed 0.1 mg/L.
- [More info](#)
47. Trichloroacetic acids are produced in drinking water as a by-product of the reaction between chlorine and naturally occurring humic and fulvic acids.
- [More info](#)
48. Natural levels of mercury in water is low, with most sources coming from industrial spills and emissions. Based on ADWG health guidelines, the concentration of total mercury should not exceed 0.001 mg/L, which is based off the toxicity of methyl mercury.
- [More info](#)

#### Unit of measures

Mg/L

Milligrams per litre.

CFU/100mL

Colony Forming Unit per 100 millilitres - used as a measure of bacterial cells.

MPN/100mL

Most Probable Number per 100 millilitres – used as a measure of bacterial cells.

µg/L

Micrograms per litre.

pH Unit

A unit of measure which describes the degree of acidity or alkalinity of a solution.

HU

Hazen Units - used as a measurement of colour.

NTU

Nephelometric Turbidity Unit – used as a measurement of turbidity.

µS/cm

MicroSiemens per centimetre – used as a measurement of conductivity.

°C

Degrees in Celsius.

ng/L

Nanogram per litre.