

Appendix A - Luggage Point AWTP Point of Supply Augmentation of Drinking Water Storage Compliance Table

Parameter	Standard	Source of Standard	Number of PRW samples collected	LN95thPercentile PRW	Number of samples detected in PRW	MaximumPRW
Total Trichlorobenzene ug/L	3.00E+01	ADWG May 2019	45	NA	1	13065
Bromate mg/L	2.00E-02	ADWG May 2019	28	NA	0	<LOR
FRNA Coliphages pfu/100mL	1.00E+00	PHR 2018, WCRWS Pathogen Verification	44	NA	1	1
Chlorate mg/L	8.00E-01	Interim DH Value 2019, WCRWS Indicator Chemical	44	3.28E-01	44	0.371
Chlorite mg/L	8.00E-01	ADWG May 2019	44	NA	3	0.251
Gross Beta (K corrected) Bq/L	5.00E-01	ADWG May 2019	46	NA	1	0.1
Diazinon ug/L	4.00E+00	ADWG May 2019, WCRWS Indicator Chemical	44	NA	1	0.56
Gross Alpha Bq/L	5.00E-01	ADWG May 2019	46	NA	2	0.07
Fluoride mg/L	1.50E+00	ADWG May 2019	39	3.66E-02	22	0.13
Nickel - Total mg/L	2.00E-02	ADWG May 2019	22	NA	6	0.001
NDMA (n-Nitrosodimethylamine)(ng/L) ng/L	1.00E+02	ADWG May 2019, WCRWS Indicator Chemical	44	NA	2	5
Bromide mg/L	7.00E+00	PHR 2018	39	1.69E-01	32	0.284
Arsenic - Total mg/L	1.00E-02	ADWG May 2019	22	NA	1	4.00E-04
Dioxin and Dioxin-like Toxic Equivalent (TEQ)(OLOR) pg/L	1.60E+01	PHR 2018	35	1.14E+04	10	0.63683
Manganese - Total mg/L	5.00E-01	ADWG May 2019	44	1.42E-02	44	0.0194
Cadmium - Total mg/L	2.00E-03	ADWG May 2019	22	6.58E-05	9	7.00E-05
Boron - Total mg/L	4.00E+00	ADWG May 2019, WCRWS Indicator Chemical	22	1.35E-01	22	0.133
Nitrate (as N) mg/L	5.00E+01	ADWG May 2019, WCRWS Indicator Chemical	24	1.33E+00	24	1.65
Iodide mg/L	5.00E-01	ADWG May 2019	24	NA	1	0.012
Dichloroacetic Acid (DCA) ug/L	1.00E+02	ADWG May 2019	44	2.17E+00	10	2
Salicylic Acid ug/L	1.00E+02	PHR 2018	36	7.44E-01	15	1.8
Total Trihalomethanes ug/L	2.50E+02	ADWG May 2019	41	3.17E+00	11	4
Chromium - Total mg/L	5.00E-02	ADWG May 2019	22	4	4	6.00E-04
Formaldehyde ug/L	5.00E+02	ADWG May 2019, WCRWS Indicator Chemical	22	4.11E+00	12	5.1
Lead - Total mg/L	1.00E-02	ADWG May 2019	22	NA	4	1.00E-04
Androsterone ng/L	1.00E+04	PHR 2018	44	NA	1	97
Silver - Total mg/L	1.00E-01	ADWG May 2019	2	NA	1	2.00E-04
Barium - Total mg/L	2.00E+00	ADWG May 2019	22	1.65E-03	18	0.0024
Copper - Total mg/L	2.00E+00	ADWG May 2019	22	NA	2	7.00E-04
4-Nonylphenol (mixture of isomers) ug/L	5.00E+02	PHR 2018, WCRWS Indicator Chemical	2	NA	1	0.13
Progesterone ng/L	1.00E+05	PHR 2018	44	NA	1	21
Naphthalene ug/L	7.00E+01	PHR 2018	41	NA	1	0.008
Bisphenol A ng/L	2.00E+05	PHR 2018	44	NA	1	12
Amitrole ug/L	9.00E-01	ADWG May 2019	1	NA	0	<LOR
Epiclorohydrin ug/L	5.00E-01	ADWG May 2019	1	NA	0	<LOR
Tributyltin (Soluble) ug/L	1.00E+00	ADWG May 2019	1	NA	0	<LOR
Acrylamide (2-propenamide) ug/L	2.00E-01	ADWG May 2019	2	NA	0	<LOR
Cyanide - Total mg/L	8.00E-02	ADWG May 2019	2	NA	0	<LOR
2,4,6-Trichlorophenol (2,4,6-T) ug/L	2.00E+01	ADWG May 2019	5	NA	0	<LOR
2,4-Dichlorophenol ug/L	2.00E+02	ADWG May 2019	5	NA	0	<LOR
2-Chlorophenol ug/L	3.00E+02	ADWG May 2019	5	NA	0	<LOR
4-Methylphenol (p-cresol) ug/L	6.00E+02	PHR 2018	5	NA	0	<LOR
Etridiazole ug/L	1.00E+02	ADWG May 2019	5	NA	0	<LOR
Metaldehyde ug/L	2.00E+01	ADWG May 2019	5	NA	0	<LOR
Phenol ug/L	2.00E+02	PHR 2018	5	NA	0	<LOR
Propylamine ug/L	7.00E+01	ADWG May 2019	5	NA	0	<LOR
4-Nitrophenol ug/L	3.00E+01	PHR 2018	6	NA	0	<LOR
Pentachlorophenol (PCP) ug/L	1.00E+01	ADWG May 2019	6	NA	0	<LOR
Terbacil ug/L	2.00E+02	ADWG May 2019	6	NA	0	<LOR
Erythromycin ug/L	2.00E+01	PHR 2018	10	NA	0	<LOR
Norfloxacin (Norflaxin) ug/L	4.00E+02	PHR 2018	11	NA	0	<LOR
Enrofloxacin ug/L	2.00E+01	PHR 2018	11	NA	0	<LOR
Norfurazone ug/L	5.00E+01	ADWG May 2019	12	NA	0	<LOR
Chlorotetracycline ug/L	1.00E+02	PHR 2018	14	NA	0	<LOR
Ciprofloxacin ug/L	2.00E+02	PHR 2018	14	NA	0	<LOR
Oxytetracycline (Terramycin) ug/L	1.00E+02	PHR 2018	14	NA	0	<LOR
Tetracycline ug/L	1.00E+02	PHR 2018	14	NA	0	<LOR
Chlorothalonil ug/L	5.00E+01	ADWG May 2019	16	NA	0	<LOR
Diflubenzuron ug/L	7.00E+01	ADWG May 2019	17	NA	0	<LOR
Thiobencarb ug/L	4.00E+01	ADWG May 2019	20	NA	0	<LOR
Diphenamid ug/L	3.00E+02	ADWG May 2019	21	NA	0	<LOR
Ethyl dipropylthiocarbamate (EPTC) ug/L	3.00E+02	ADWG May 2019	21	NA	0	<LOR
Fenarimol ug/L	4.00E+01	ADWG May 2019	21	NA	0	<LOR
Fensulfotion ug/L	1.00E+01	ADWG May 2019	21	NA	0	<LOR
Fenthion ug/L	7.00E+00	ADWG May 2019	21	NA	0	<LOR
Glyphosate - Total ug/L	1.00E+03	ADWG May 2019, WCRWS Indicator Chemical	21	NA	0	<LOR
Nitralin ug/L	5.00E+02	ADWG May 2019	21	NA	0	<LOR
Pirimiphos-ethyl ug/L	9.00E+01	ADWG May 2019	21	NA	0	<LOR
Pyroxsulam ug/L	4.00E+03	ADWG May 2019	21	NA	0	<LOR
Spirotetramat ug/L	2.00E+02	ADWG May 2019	21	NA	0	<LOR
Thiometon ug/L	4.00E+00	ADWG May 2019	21	NA	0	<LOR
Toltrazuril ug/L	4.00E+00	ADWG May 2019	21	NA	0	<LOR
Trichlorfon ug/L	7.00E+00	ADWG May 2019	21	NA	0	<LOR
Vernolate ug/L	4.00E+01	ADWG May 2019	21	NA	0	<LOR
3-Hydroxycarbofuran ug/L	5.00E-01	PHR 2018	22	NA	0	<LOR
Acenaphthylene ug/L	4.00E+02	PHR 2018	22	NA	0	<LOR
Aldicarb - Total ug/L	4.00E+00	ADWG May 2019	22	NA	0	<LOR
Antimony - Total mg/L	3.00E-03	ADWG May 2019	22	NA	0	<LOR
Benzo(a)pyrene ug/L	1.00E-02	ADWG May 2019	22	NA	0	<LOR
Carbendazim - Total ug/L	9.00E+01	ADWG May 2019	22	NA	0	<LOR
Carbofuran - Total ug/L	1.00E+01	ADWG May 2019	22	NA	0	<LOR
Ethylenediamine tetraacetic acid (EDTA) ug/L	2.50E+02	ADWG May 2019, WCRWS Indicator Chemical	22	NA	0	<LOR
Methiocarb ug/L	7.00E+00	ADWG May 2019	22	NA	0	<LOR
Methomyl - Total ug/L	2.00E+01	ADWG May 2019	22	NA	0	<LOR
Molybdenum - Total mg/L	5.00E-02	ADWG May 2019	22	NA	0	<LOR
Nitrioltriacetic Acid (NTA) ug/L	2.00E+02	ADWG May 2019	22	NA	0	<LOR
Oxamyl - Total ug/L	7.00E+00	ADWG May 2019	22	NA	0	<LOR
Selenium - Total mg/L	1.00E-02	ADWG May 2019	22	NA	0	<LOR
Nitrite (as N) mg/L	3.00E+00	ADWG May 2019	24	NA	0	<LOR
Carbaryl ug/L	3.00E+01	ADWG May 2019	32	NA	0	<LOR
Total Xylene ug/L	6.00E+02	ADWG May 2019	39	NA	0	<LOR
Bromoxynil ug/L	1.00E+01	ADWG May 2019	41	NA	0	<LOR
Hydroxyatrazine ug/L	2.00E+02	PHR 2018	41	NA	0	<LOR
Temephos ug/L	4.00E+02	ADWG May 2019	41	NA	0	<LOR
1,2-Dichlorobenzene ug/L	1.50E+03	ADWG May 2019	42	NA	0	<LOR
1,2-Dichloroethane ug/L	3.00E+00	ADWG May 2019	42	NA	0	<LOR
Benzene ug/L	1.00E+00	ADWG May 2019	42	NA	0	<LOR
DEET ug/L	2.00E+03	PHR 2018	42	NA	0	<LOR
Ethylbenzene ug/L	3.00E+02	ADWG May 2019	42	NA	0	<LOR
Hexachlorobutadiene ug/L	7.00E-01	ADWG May 2019	42	NA	0	<LOR
Tetrachloroethene ug/L	5.00E+01	ADWG May 2019	42	NA	0	<LOR
Toluene ug/L	8.00E+02	ADWG May 2019	42	NA	0	<LOR
Vinyl Chloride ug/L	3.00E-01	ADWG May 2019	42	NA	0	<LOR
3,4-Dichloroaniline (3,4-DCA) ug/L	9.00E+01	PHR 2018	43	NA	0	<LOR
Ametryn ug/L	7.00E+01	ADWG May 2019	43	NA	0	<LOR
Atrazine ug/L	2.00E+01	ADWG May 2019	43	NA	0	<LOR
Bromacil ug/L	4.00E+02	ADWG May 2019	43	NA	0	<LOR
Fluometuron ug/L	7.00E+01	ADWG May 2019	43	NA	0	<LOR
Haloxypop - Total ug/L	1.00E+00	ADWG May 2019	43	NA	0	<LOR
Hexazinone ug/L	4.00E+02	ADWG May 2019	43	NA	0	<LOR
Metolachlor ug/L	3.00E+02	ADWG May 2019	43	NA	0	<LOR
1,1-Dichloroethene ug/L	3.00E+01	ADWG May 2019	44	NA	0	<LOR
1,2-Dibromoethane (EDB) ug/L	1.00E+00	ADWG May 2019	44	NA	0	<LOR
1,2-Dichloroethene ug/L	6.00E+01	ADWG May 2019	44	NA	0	<LOR
1,4-Dichlorobenzene ug/L	4.00E+01	ADWG May 2019	44	NA	0	<LOR
17-alpha-Estradiol ng/L	2.00E+02	PHR 2018	44	NA	0	<LOR
17-alpha-ethynylestradiol ng/L	2.00E+00	PHR 2018	44	NA	0	<LOR
17-beta-estradiol ng/L	2.00E+02	PHR 2018	44	NA	0	<LOR
1H-Benzotriazole, 5-Methyl ug/L	5.00E+02	PHR 2018	44	NA	0	<LOR
2,2-Dichloropropionic acid (DPA) (Dalapon) ug/L	5.00E+02	ADWG May 2019	44	NA	0	<LOR
2,4-Dichlorophenoxyacetic acid (2,4-D) ug/L	3.00E+01	ADWG May 2019	44	NA	0	<LOR
2,4-Dichlorophenoxypropionic acid (2,4-DP) (Dichlorprop) ug/L	1.00E+02	ADWG May 2019	44	NA	0	<LOR
2,6-Di-t-butylphenol ug/L	5.00E+01	PHR 2018	44	NA	0	<LOR
4-t-Octylphenol ng/L	5.00E+04	PHR 2018	44	NA	0	<LOR
Alprazolam (Xanax) ug/L	2.00E-01	PHR 2018	44	NA	0	<LOR
Amitraz ug/L	9.00E+00	ADWG May 2019	44	NA	0	<LOR
Asulam ug/L	7.00E+01	ADWG May 2019	44	NA	0	<LOR
Atenolol ug/L	2.00E+01	PHR 2018	44	NA	0	<LOR
Atorvastatin ug/L	5.00E+00	PHR 2018	44	NA	0	<LOR
Azinphos-methyl (Guthion) ug/L	3.00E+01	ADWG May 2019	44	NA	0	<LOR
Betaxolol ug/L	1.00E+01	PHR 2018	44	NA	0	<LOR
Bioresmethrin ug/L	1.00E+02	ADWG May 2019	44	NA	0	<LOR
Bromochloromethane ug/L	4.00E+01	PHR 2018	44	NA	0	<LOR
Bromophos-ethyl ug/L	1.00E+01	ADWG May 2019	44	NA	0	<LOR
Butylated hydroxytoluene (2,6-Di-tert-Butyl-p-Cresol) (BHT) ug/L	1.00E+03	PHR 2018	44	NA	0	<LOR
Captan ug/L	4.00E+02	ADWG May 2019	44	NA	0	<LOR
Carbamazepine ug/L	1.00E+02	PHR 2018, WCRWS Indicator Chemical	44	NA	0	<LOR
Carbon tetrachloride ug/L	3.00E+00	ADWG May 2019	44	NA	0	<LOR
Carbophenothion ug/L	5.00E-01	ADWG May 2019	44	NA	0	<LOR
Cephalaxin ug/L	4.00E+01	PHR 2018	44	NA	0	<LOR
Chloramphenicol ug/L	2.00E+02	PHR 2018	44	NA	0	<LOR
Chlordane - Total ug/L	2.00E+00	ADWG May 2019	44	NA	0	<LOR
Chlorfenvinphos ug/L	2.00E+00	ADWG May 2019	44	NA	0	<LOR
Chlorobenzene ug/L	3.00E+02	ADWG May 2019	44	NA	0	<LOR
Chlorpyrifos ug/L	1.00E+01	ADWG May 2019	44	NA	0	<LOR
Chlorpyrifos-methyl ug/L	1.00E+01	PHR 2018	44	NA	0	<LOR
Citalopram ug/L	1.00E+01	PHR 2018	44	NA	0	<LOR
Clopyralid ug/L	2.00E+03	ADWG May 2019	44	NA	0	<LOR
Clostridium pefringes cfu/100ml	1.00E+00	PHR 2018, WCRWS Pathogen Verification	44	NA	0	<LOR
Codeine ug/L	5.00E+01	PHR 2018	44	NA	0	<LOR
Cyclophosphamide ug/L	4.00E+00	PHR 2018	44	NA	0	<LOR
Cyfluthrin ug/L	5.00E+01	ADWG May 2019	44	NA	0	<LOR
Cypermethrin ug/L	2.00E+02	ADWG May 2019	44	NA	0	<LOR
DDE (pp) (4,4-DDE) ug/L	2.00E+01	PHR 2018	44	NA	0	<LOR
DDT - Total ug/L	9.00E+00	ADWG May 2019	44	NA	0	<LOR
Deltamethrin ug/L	4.00E+01	ADWG May 2019	44	NA	0	<LOR
Demeton-S ug/L	2.00E-01	PHR 2018	44	NA	0	<LOR
Diazepam (Valium) including Desmethy Diazepam (Nordazepam) ug/L	2.00E+00	PHR 2018	44	NA	0	<LOR
Dicamba ug/L	1.00E+02	ADWG May 2019	44	NA	0	<LOR
Dichloromethane (Methylene chloride) ug/L	4.00E+00	ADWG May 2019	44	NA	0	<LOR
Dichlorvos ug/L	5.00E+00	ADWG May 2019	44	NA	0	<LOR
Diclofenac ug/L	2.00E+00	PHR 2018	44	NA	0	<LOR
Diclofop-methyl ug/L	5.00E+00	ADWG May 2019	44	NA	0	<LOR
Dicofol ug/L	4.00E+00	ADWG May 2019	44	NA	0	<LOR
Dimethoate ug/L	7.00E+00	ADWG May 2019	44	NA	0	<LOR
Disulfoton ug/L	4.00E+00	ADWG May 2019	44	NA	0	<LOR
Diuron ug/L	2.00E+01	ADWG May 2019, WCRWS Indicator Chemical	44	NA	0	<LOR

Parameter	Standard	Source of Standard	Number of PRW samples collected	LN95thPercentile PRW	Number of samples detected in PRW	MaximumPRW
Endosulfan - Total ug/L	2.00E+01	ADWG May 2019	44	NA	0	<LOR
Equilenin ng/L	3.00E+01	PHR 2018	44	NA	0	<LOR
Equilin ng/L	3.00E+01	PHR 2018	44	NA	0	<LOR
Erythromycin Anhydrate ug/L	2.00E+01	PHR 2018	44	NA	0	<LOR
Escherichia coli (E. coli) cfu/100ml	1.00E+00	PHR 2018, WCRWS Pathogen Verification	44	NA	0	<LOR
Estriol ng/L	5.00E+01	PHR 2018	44	NA	0	<LOR
Estrone ng/L	3.00E+01	PHR 2018	44	NA	0	<LOR
Ethion ug/L	4.00E+00	ADWG May 2019	44	NA	0	<LOR
Ethoprophos (Mocap) ug/L	1.00E+00	ADWG May 2019	44	NA	0	<LOR
Fenamiphos ug/L	5.00E-01	ADWG May 2019	44	NA	0	<LOR
Fenitrothion ug/L	7.00E+00	ADWG May 2019	44	NA	0	<LOR
Fenoprop (2,4,5-TP) Silvex ug/L	1.00E+01	ADWG May 2019	44	NA	0	<LOR
Fenvalerate ug/L	6.00E+01	ADWG May 2019	44	NA	0	<LOR
Fipronil - Total ug/L	7.00E-01	ADWG May 2019	44	NA	0	<LOR
Flamprop-methyl ug/L	4.00E+00	ADWG May 2019	44	NA	0	<LOR
Fluoxetine (Prozac) ug/L	1.00E+01	PHR 2018	44	NA	0	<LOR
Fluroxypyr ug/L	7.00E+02	PHR 2018	44	NA	0	<LOR
Fruzemide (Furosemide) ug/L	1.00E+01	PHR 2018	44	NA	0	<LOR
Galaxolide ug/L	2.00E+03	PHR 2018, WCRWS Indicator Chemical	44	NA	0	<LOR
Gemfibrozil (Gemfibrozil) ug/L	6.00E+02	PHR 2018, WCRWS Indicator Chemical	44	NA	0	<LOR
Haloxypop-methyl ug/L	2.00E-01	PHR 2018	44	NA	0	<LOR
HCH gamma (gamma-Lindane) ug/L	1.00E+01	ADWG May 2019	44	NA	0	<LOR
Heptachlor - Total ug/L	3.00E-01	ADWG May 2019	44	NA	0	<LOR
Hydrochlorothiazide ug/L	1.00E+01	PHR 2018, WCRWS Indicator Chemical	44	NA	0	<LOR
Ibuprofen ug/L	4.00E+02	PHR 2018	44	NA	0	<LOR
Imazapyr ug/L	9.00E+03	ADWG May 2019	44	NA	0	<LOR
Imidacloprid ug/L	2.00E+02	Interim DH Value 2019	44	NA	0	<LOR
Indomethacin ug/L	2.00E+01	PHR 2018	44	NA	0	<LOR
Iopromide ug/L	8.00E+02	PHR 2018	44	NA	0	<LOR
Isophosphamide (fosfamide) ug/L	4.00E+00	PHR 2018	44	NA	0	<LOR
Lanthanum - Total mg/L	2.00E-03	ADWG May 2019	44	NA	0	<LOR
Lincocmycin ug/L	4.00E+03	PHR 2018	44	NA	0	<LOR
Malathion (Maldison) ug/L	7.00E+01	ADWG May 2019	44	NA	0	<LOR
MCPA (2-Methyl-4-chlorophenoxyacetic acid) ug/L	4.00E+01	ADWG May 2019, WCRWS Indicator Chemical	44	NA	0	<LOR
Mecoprop ug/L	1.00E+01	PHR 2018	44	NA	0	<LOR
Mestranol ng/L	2.00E+00	PHR 2018	44	NA	0	<LOR
Methidathion ug/L	6.00E+00	ADWG May 2019	44	NA	0	<LOR
Methoxychlor ug/L	3.00E+02	ADWG May 2019	44	NA	0	<LOR
Methyl Bromide (Bromomethane) ug/L	1.00E+00	ADWG May 2019	44	NA	0	<LOR
Metoprolol ug/L	2.00E+01	PHR 2018	44	NA	0	<LOR
Metribuzin ug/L	7.00E+01	ADWG May 2019	44	NA	0	<LOR
Metsulfuron-methyl ug/L	4.00E+01	ADWG May 2019	44	NA	0	<LOR
Mevinphos ug/L	5.00E+00	ADWG May 2019	44	NA	0	<LOR
Molinate ug/L	4.00E+00	ADWG May 2019	44	NA	0	<LOR
Monochloroacetic Acid (MCA) ug/L	1.50E+02	ADWG May 2019	44	NA	0	<LOR
Monocrotophos ug/L	2.00E+00	ADWG May 2019	44	NA	0	<LOR
Musk Ketone ug/L	4.00E+02	PHR 2018	44	NA	0	<LOR
Musk Xylene ug/L	4.00E+02	PHR 2018	44	NA	0	<LOR
Napropamide ug/L	4.00E+02	ADWG May 2019	44	NA	0	<LOR
Naproxen ug/L	2.00E+02	PHR 2018	44	NA	0	<LOR
NDEA (n-Nitrosodiethylamine) ng/L	1.00E+01	PHR 2018	44	NA	0	<LOR
NMOR (n-Nitrosomorpholine) ng/L	1.00E+00	PHR 2018	44	NA	0	<LOR
Norethindrone (Norethisterone) ng/L	2.00E+02	PHR 2018	44	NA	0	<LOR
Omethoate ug/L	1.00E+00	ADWG May 2019	44	NA	0	<LOR
Oxazepam ug/L	2.00E+01	PHR 2018	44	NA	0	<LOR
Oxycodone ug/L	1.00E+01	PHR 2018	44	NA	0	<LOR
Paracetamol (acetaminophen) ug/L	2.00E+02	PHR 2018	44	NA	0	<LOR
Parathion (ethyl) ug/L	2.00E+01	ADWG May 2019	44	NA	0	<LOR
Parathion (methyl) ug/L	7.00E-01	ADWG May 2019	44	NA	0	<LOR
Pendimethalin ug/L	4.00E+02	ADWG May 2019	44	NA	0	<LOR
Permethrin ug/L	2.00E+02	ADWG May 2019	44	NA	0	<LOR
Picloram ug/L	3.00E+02	ADWG May 2019	44	NA	0	<LOR
Piperonyl Butoxide ug/L	6.00E+02	ADWG May 2019	44	NA	0	<LOR
Pirimicarb ug/L	7.00E+00	ADWG May 2019	44	NA	0	<LOR
Pirimiphos-methyl ug/L	5.00E-01	ADWG May 2019	44	NA	0	<LOR
Praziquantel ug/L	7.00E+01	PHR 2018	44	NA	0	<LOR
Profenofos ug/L	3.00E-01	ADWG May 2019	44	NA	0	<LOR
Prometryn ug/L	1.00E+02	PHR 2018	44	NA	0	<LOR
Propachlor ug/L	7.00E+01	ADWG May 2019	44	NA	0	<LOR
Propanil ug/L	7.00E+02	ADWG May 2019	44	NA	0	<LOR
Propargite ug/L	7.00E+00	ADWG May 2019	44	NA	0	<LOR
Propazine ug/L	5.00E+01	ADWG May 2019	44	NA	0	<LOR
Propiconazole ug/L	1.00E+02	ADWG May 2019	44	NA	0	<LOR
Propoxur ug/L	7.00E+01	PHR 2018	44	NA	0	<LOR
Propranolol ug/L	4.00E+01	PHR 2018	44	NA	0	<LOR
Pyrazophos ug/L	2.00E+01	ADWG May 2019	44	NA	0	<LOR
Ranitidine ug/L	8.00E+01	PHR 2018	44	NA	0	<LOR
Roxithromycin ug/L	2.00E+02	PHR 2018	44	NA	0	<LOR
Simazine ug/L	2.00E+01	ADWG May 2019	44	NA	0	<LOR
Somatic Coliphages pfu/100ml	1.00E+00	PHR 2018, WCRWS Pathogen Verification	44	NA	0	<LOR
Styrene (Vinyl benzene) ug/L	3.00E+01	ADWG May 2019	44	NA	0	<LOR
Sulfadiazine (Sulphadiazine) ug/L	1.00E+03	PHR 2018	44	NA	0	<LOR
Sulfamethoxazole (Sulphamethoxazole) ug/L	2.00E+02	PHR 2018	44	NA	0	<LOR
Sulfasalazine ug/L	5.00E+02	PHR 2018	44	NA	0	<LOR
Sulfathiazole (Sulphathiazole) ug/L	4.00E+01	PHR 2018	44	NA	0	<LOR
Sulprofos ug/L	1.00E+01	ADWG May 2019	44	NA	0	<LOR
Temazepam ug/L	5.00E+00	PHR 2018	44	NA	0	<LOR
Terbufos ug/L	9.00E-01	ADWG May 2019	44	NA	0	<LOR
Terbutylazine ug/L	1.00E+01	ADWG May 2019	44	NA	0	<LOR
Terbutryn ug/L	4.00E+02	ADWG May 2019	44	NA	0	<LOR
Testosterone ng/L	7.00E+03	PHR 2018	44	NA	0	<LOR
Tetrachlorvinphos ug/L	1.00E+02	ADWG May 2019	44	NA	0	<LOR
Theophylline ug/L	2.00E+02	PHR 2018	44	NA	0	<LOR
Tonalide (6-Acetyl-1, 1, 2, 4, 4, 7-hexamethyltetraline) ug/L	2.00E+01	PHR 2018	44	NA	0	<LOR
Total 1,3-Dichloropropene ug/L	1.00E+02	ADWG May 2019	44	NA	0	<LOR
Total Aldrin & Dieldrin ug/L	3.00E-01	ADWG May 2019	44	NA	0	<LOR
Triadimefon - Total ug/L	9.00E+01	ADWG May 2019	44	NA	0	<LOR
Trichloroacetic Acid ug/L	1.00E+02	ADWG May 2019	44	NA	0	<LOR
Trichlorophenoxyacetic acid (2,4,5-T) ug/L	1.00E+02	ADWG May 2019	44	NA	0	<LOR
Triclopyr ug/L	2.00E+01	ADWG May 2019	44	NA	0	<LOR
Triclosan ug/L	1.00E+03	PHR 2018	44	NA	0	<LOR
Trifluralin ug/L	9.00E+01	ADWG May 2019	44	NA	0	<LOR
Trimethoprim ug/L	7.00E+01	PHR 2018	44	NA	0	<LOR
Tris(2-chloroethyl)phosphate (TCEP) ug/L	8.00E+01	PHR 2018	44	NA	0	<LOR
Tris(dichloropropyl) phosphate (Fyrol) ug/L	1.00E+00	PHR 2018	44	NA	0	<LOR
Tylosin ug/L	1.00E+03	PHR 2018	44	NA	0	<LOR
Venlafaxine ug/L	4.00E+01	PHR 2018	44	NA	0	<LOR
Warfarin ug/L	1.00E+00	PHR 2018	44	NA	0	<LOR