

Drinking Water Quality Management Plan Annual Report 2021-2022



Revision 01 | December 2022



Distribution list

Name	Title
Department of Regional Development, Manufacturing and Water	Water Supply Regulator

This document is the property of Seqwater and its issue is controlled.

The information contained herein may not be disclosed in whole or in part, either verbally or in writing, without the prior consent of Seqwater.

Document control

Approved for issue			
Date	Name	Position	Signature
15/12/2022 10:34 AEST	Duncan Middleton	(Acting) Manager Technical Support and Improvement Seqwater	DocuSigned by: <i>Duncan Middleton</i> 59211D5DC47C4BD...

Rev. no.	Doc No.	Doc Owner	Version Date	Doc Approver
01	D22/322151	Principal Water Quality	19/12/2022	Manager – Technical Support and Improvement

Contents

1	Executive summary	4
2	Introduction	6
	2.1 Purpose	6
	2.2 Plan overview	7
3	Implementation of the DWQMP	9
	3.1 Approval conditions	9
	3.2 Risk assessment	11
	3.3 Operational monitoring	12
	3.4 Verification monitoring	18
4	Improvement plan	24
5	Drinking water quality incidents	26
6	Audit of the Plans	28
	6.1 Regular audits	28
	6.2 Audits – water treatment and Supply System operations	28
7	Regular review of the plan	30
8	Glossary	31
9	Enclosures	33

Tables

Table 1 - Regulated Conditions and Implemented Compliance	7
Table 2 - Conditional Approval and Compliance	10
Table 3 - Preventive Barriers in Water Treatment	13
Table 4 - Preventive Measures in the Supply System	15
Table 5 - WTP Verification Monitoring Summary	19
Table 6 - Supply system verification monitoring summary.	22
Table 7 - A summary of incidents at Seqwater’s treatment operations and Supply System	26

Figures

Figure 1 – WTP exceedances over different reporting periods	21
Figure 2 - Supply System exceedances over different reporting periods	23

Rev. no.	Doc No.	Doc Owner	Version Date	Doc Approver
01	D22/322151	Principal Water Quality	19/12/2022	Manager – Technical Support and Improvement

1 Executive summary

The Queensland Bulk Water Supply Authority trading as Seqwater (SPID 507) is responsible for South East Queensland's bulk water supply system. This includes catchments, storages, water treatment plants and bulk transport infrastructure along with several small reticulation systems supplying recreation parks.

Seqwater's Drinking Water Quality Management Plan Report (**report**) outlines the activities for the management of water quality risk and issues. The report covers the period from 1 July 2021 to 30 June 2022 (**reporting period**), during which Seqwater complied with the approval conditions of its Drinking Water Quality Management Plan (**DWQMP**).

Seqwater's operational and verification monitoring programs have occurred in accordance with the criteria documented in the approved DWQMP. Operational monitoring includes online monitoring with process instrumentation and operator testing designed to assess the performance of preventive measures and requirements for corrective actions. Verification monitoring involves a sampling and analytical testing program. Sampling and some on-site analyses are undertaken by Seqwater, with the majority of analytical testing undertaken by an external National Association of Testing Authorities (**NATA**) accredited laboratory. Verification monitoring during the reporting period included 32,416 tests of treated water at individual water treatment plants, and 58,546 supply system drinking water tests.

Seqwater also completed catchment and source water risk characterisation and monitoring activities, including catchment surveys and deployment of passive samplers to detect micro-pollutants. These activities help identify changes to the source water risk profile and support Seqwater operations by enabling informed decisions about daily operations, water security and supply planning.

Seqwater was compliant with the microbiological and health requirements in the *Public Health Regulation 2018* during the 2021-22 reporting period for all of its water treatment operations and supply system zones. Water treatment and supply system verification testing against the water quality criteria in the DWQMP detected three individual health-related exceedances (*E.coli*) at two water treatment plants (**WTP**) and an unrelated Supply System offtake on 24 March 2022. These occurred at a time when there were no operational issues and normal chlorine disinfection levels. An investigation found that these results were related to contamination at a point during the process of sample bottle preparation, sample transport or laboratory testing that affected two sample runs in the northern operational region.

There were nine aesthetic exceedances detected within the routine verification monitoring program within the reporting period. These predominantly related to elevated hardness at Linville WTP with five exceedances due to source water conditions and limitations in the treatment capability for reducing hardness at this site. The remaining exceedances concerned elevated pH at North Pine WTP during adverse raw water conditions and issues concerning representative sampling at the Aspley Water Quality Management Facility (**WQMF**) resulting in two high ammonia and one high pH results which were found to be inconsistent with online and downstream monitoring. Improvements for each of these sites are being considered through Seqwater's planning processes.

There were two reportable events during the reporting period. Firstly, filtered water turbidity monitoring failed to interlock plant operation at Wivenhoe Dam WTP (Recreational site) resulting in a delayed shutdown of the plant. The reticulation system in the Cormorant Bay recreation park was flushed and water cartage from another nearby water supply scheme has since been used for ongoing supply arrangements. Secondly, an overflow occurred at the Kimberley Park Reservoir's Break of Head tank where the overflowing water entered an elevated pump room which then resulted in a small volume of potentially contaminated water returning to the Break of Head tank at a time when total chlorine levels were low. Further investigation found the fault in tank level sensing was due to a leaking pump which was repaired. The investigation identified additional improvements that are progressing through Seqwater's planning processes. These incidents were reported to

Rev. no.	Doc No.	Doc Owner	Version Date	Doc Approver
01	D22/322151	Principal Water Quality	19/12/2022	Manager – Technical Support and Improvement

the Water Supply Regulator (**WSR or the Regulator**) within the required timeframes. Seqwater's management of these events has been compliant with its DWQMP.

Seqwater reported a third event, which was a detection of fipronil in the raw water at Leslie Harrison Dam. This detection was investigated and found to be due to analytical error. The result was re-issued by the laboratory and complied with the Australian Drinking Water Guideline value. The Regulator subsequently determined this was a non-reportable event but is noted here for completeness.

Consistently low numbers of exceedances and reportable events across a large and complex system during the last few years, including 2021-22, reflects the achievements made through the continuous improvement of Seqwater's drinking water assets and drinking water quality management system.

Other drinking water quality management system improvement activities completed during the reporting period include eight risk assessment reviews, 22 HACCP team meetings, 17 internal audits of treatment plants and supply system sites, and an external third-party audit to maintain ISO 22000 certification. COVID restrictions limited site access for the internal audit program and reduced the number of audits conducted during 2021. Some audits including the external third-party audit were conducted remotely. A regular audit and a review of the DWQMP were not required to be undertaken during the reporting period.

These reviews and audits are part of a schedule that encompasses all of Seqwater's treatment plants and supply system sites and the findings were used to improve the drinking water quality management system. Long-term improvement initiatives identified through these assessments and reviews have been captured in a consolidated Drinking Water Quality Improvement Plan.

Rev. no.	Doc No.	Doc Owner	Version Date	Doc Approver
01	D22/322151	Principal Water Quality	19/12/2022	Manager – Technical Support and Improvement

2 Introduction

This is the 2021-2022 DWQMP report for Seqwater, a registered service provider with identification (**SPID**) number SP507. Seqwater operates raw water storage, bulk treatment and transport assets from Noosa to the Gold Coast region and across to the base of the Great Dividing Range. Seqwater has responsibility for managing 32 operational WTPs, a desalination plant, 26 dams and 48 weirs. Not all of this infrastructure is related to the supply of drinking water, as some of the dams and weirs are used for irrigation schemes. Seqwater has nine WTPs and a desalination plant connected to the Supply System, 19 WTPs (including the offline Banksia Beach WTP) directly connected to SEQ Water Service Providers and five recreational WTPs operated solely for Seqwater's recreational sites and supporting assets. Only those WTPs and Supply System components operated for the supply of drinking water are included in the Seqwater DWQMP and this report.

Seqwater is operating under an approved DWQMP to ensure consistent supply of safe, high quality drinking water in order to protect public health. This is achieved through proactive identification and minimisation of public health-related risks associated with drinking water.

This DWQMP report includes:

- the activities undertaken over the financial year in operating our drinking water service
- drinking water quality summary
- summary of our performance implementing our approved DWQMP.

This report is submitted to the WSR to fulfil our regulatory requirement under the *Water Supply (Safety and Reliability) Act 2008* (Qld) (**the Act**). This report is made publicly available to our customers and the South East Queensland community through our website, or for inspection upon request at Seqwater's Head Office during office hours on business days.

2.1 Purpose

This DWQMP report has been prepared in accordance with section 142 of the Act (refer to Table 1). The purpose of this DWQMP report is to provide the Regulator with information on the overall performance of the DWQMP for the reporting period 1 July 2021 to 30 June 2022. This report also provides an accountability mechanism to our customers and communities.

Rev. no.	Doc No.	Doc Owner	Version Date	Doc Approver
01	D22/322151	Principal Water Quality	19/12/2022	Manager – Technical Support and Improvement

Table 1 Regulated Conditions and Implemented Compliance

DWQMP Report Condition	Seqwater Compliance
<p>Section 142 Drinking water quality management plan reports</p> <p>This section applies for each financial year after a financial year in which a relevant service provider's drinking water quality management plan has been approved.</p> <p>The provider must, unless the provider has a reasonable excuse—</p> <ul style="list-style-type: none"> • prepare a report (a drinking water quality management plan report) for the financial year complying with this section and, if section 142C(2) applies to the provider, that subsection; and • give the regulator a copy of the report within 120 business days after the financial year ends. 	<p>The current report is required to be submitted to the Regulator within 120 business days after the 2021-22 financial year ends. As outlined in the Information Notice, submission for this report is due by 19 December 2022.</p> <p>This report has been prepared in accordance with the approval conditions of the DWQMP and the Drinking Water Quality Management Plan Report Guidance Notes.</p> <p>Section 142C(2) is not applicable.</p>
<p>Section 142(3) The report must state or include all of the following—</p>	<p>This report provides an update on the implementation of the DWQMP in accordance with the approval conditions and the above regulatory guidance.</p> <p>Refer to Section 3 of this report.</p> <p>Refer to Section 7 of this report. A regular review of the DWQMP was not required to be completed in the reporting period.</p> <p>Refer to Section 6 of this report. A regular audit of the DWQMP was not required to be completed during the reporting period.</p> <p>Refer to Section 5 of this report for details of incident/event reporting during the reporting period.</p> <p>Refer to Sections 3 and 5 of this report. Enclosure 1 provides the 2021-22 Water Quality Data report. This report also includes aesthetic criteria.</p> <p>Seqwater does not supply drinking water directly to customers (as defined under the Act). Customer complaints are managed by Water Service Providers (WSPs), with the exception of the small recreation park systems operated by Seqwater where there have been no recorded complaints. Accordingly, complaints are not detailed in this report.</p>
a. the information required under the latest reporting requirement given to the provider;	
b. the actions the provider took to implement the plan;	
c. the outcome of any review of the plan in the financial year and how the provider has addressed matters raised in the review;	
d. if a drinking water quality management plan audit report has been prepared for the financial year— a summary of its findings and any recommendations;	
e. details of any information the provider gave the regulator under sections 102 and 102A in the financial year;	
f. details of the provider's compliance with water quality criteria for drinking water;	
g. if the provider supplies drinking water to customers— details of any complaints to the provider about the provider's drinking water service.	

2.2 Plan overview

Seqwater must comply with the DWQMP approved by the Regulator and developed under the Act. The DWQMP forms part of the corporate drinking water quality management system Seqwater has implemented to cover the drinking water assets and activities captured by the Act. The Seqwater water quality management

Rev. no.	Doc No.	Doc Owner	Version Date	Doc Approver
01	D22/322151	Principal Water Quality	19/12/2022	Manager – Technical Support and Improvement

system has been developed to be consistent with the *Drinking Water Quality Management Plan Guideline* (2018) issued under the Act as well as the Framework for the Management of Drinking Water Quality within the *Australian Drinking Water Guidelines (ADWG, 2011)*. Accordingly, Seqwater adopts the multi-barrier approach for drinking water quality management.

Seqwater currently has responsibilities across all these barriers, which include:

- Catchments
- Storages and dams
- Water treatment
- Disinfection
- Supply systems
- Distribution systems in recreation areas.

The DWQMP covers the drinking water quality management activities of Seqwater for all drinking water treatment plants and the bulk water supply systems managed by Seqwater. Accordingly, the plan applies to barriers from selective abstraction of the raw water to the management of bulk water supply assets and small distribution networks in Seqwater's recreation areas.

The final barriers in the reticulated distribution system are predominantly managed by downstream WSPs who provide distribution and connections with consumers in all systems except for Seqwater's recreation areas.

Rev. no.	Doc No.	Doc Owner	Version Date	Doc Approver
01	D22/322151	Principal Water Quality	19/12/2022	Manager – Technical Support and Improvement

3 Implementation of the DWQMP

A revised and updated version of Seqwater’s DWQMP was reviewed and submitted to the Regulator during the previous reporting period (11 August 2020). Seqwater received approval from the Regulator under Information Notice dated 15 March 2021 (**Information Notice**) for the revised and updated DWQMP. Seqwater’s compliance with the conditions in the Information Notice for its approved DWQMP is detailed in Section 3.1 of this report.

Amendments to the DWQMP were made in accordance with section 99A of the Act. The DWQMP amendments included various minor changes to the DWQMP and associated site-based HACCP plans and procedures identified in the DWQMP review. Additionally, the currency of the DWQMP and site-based HACCP plans (sub-plans) have been reviewed through the ongoing continuous improvement activities detailed in Section 7 of this report.

The risk assessment reviews completed during the reporting period are detailed in Section 3.2 of this report. Changes to the DWQMP and site-based HACCP plans are detailed in Enclosure 4.

Seqwater maintains an operational monitoring program which supports the multiple-barrier approach to effectively manage drinking water quality as described in Section 3.3. This includes monitoring of key operational parameters by online instrumentation that feed into Supervisory Control and Data Acquisition (**SCADA**) systems as well as the operational monitoring performed by water treatment plant operators and internal process laboratories. The operator and process laboratory monitoring is used to verify the operation of the plant and the accuracy of online instrumentation. There have been no significant revisions to the operational monitoring program during the reporting period.

Seqwater’s verification monitoring program covers a wide range of parameters determined using a risk-based approach. These are detailed in the DWQMP. The results of Seqwater’s verification monitoring during the reporting period are described in Section 3.4 of this report and a detailed data report in the format prescribed by the Regulator is provided in Enclosure 1. Analysis of verification samples was undertaken primarily by an external NATA-accredited laboratory. Seqwater undertakes sampling and specific analysis that supports operations, while also informing verification monitoring, underpinned by a laboratory quality management system based on ISO 170025. This analysis includes on-site field tests and parameters analysed at Seqwater Process Laboratories, such as Taste and Odour compounds. In addition, the Seqwater verification monitoring program includes aspects at the cutting edge of modern monitoring. This analysis is undertaken by specialist laboratories that have implemented rigorous quality systems, based on ISO 17025. All verification monitoring results are recorded in the Seqwater’s Laboratory Information Management System (**LIMS**). Seqwater reviews the verification monitoring program on a quarterly basis.

Seqwater has continued to improve its drinking water quality management system. Actions in the risk management improvement program, known as the Drinking Water Quality Improvement Plan (**DWQIP**) were implemented during the 2021-22 reporting period as described in Section 4 of this report. The DWQIP changes during 2021-22 are provided in Enclosure 3 to this report.

3.1 Approval conditions

As outlined above, the Regulator provided approval of Seqwater’s amended DWQMP on 15 March 2021, prior to the commencement of the 2021-22 reporting period. Under an Information Notice given pursuant to section 99(1)(b) of the Act, Seqwater’s amended DWQMP was formally approved by the Regulator. The approval conditions and Seqwater’s compliance with these conditions, are detailed in Table 2 below.

Rev. no.	Doc No.	Doc Owner	Version Date	Doc Approver
01	D22/322151	Principal Water Quality	19/12/2022	Manager – Technical Support and Improvement

Table 2 Conditional Approval and Compliance

Condition	Compliance
No. 1. Water Quality Criteria	
<p>Water quality criteria for drinking water including:</p> <ol style="list-style-type: none"> i. The standards for drinking water quality prescribed in a regulation under the <i>Public Health Act 2005</i> (Qld) (Public Health Act). ii. The criteria in any guideline, if any, made by the Regulator about the quality of drinking water. iii. The criteria for drinking water made in a condition applicable to the DWQMP. <p>For the purpose of (iii), the following applies:</p> <p>All parameters that have health guideline values in the ADWG are deemed to be water quality criteria that apply to this DWQMP. Parameters with only aesthetic guideline values are not considered to be water quality criteria and are not required to be reported.</p> <p>Seqwater is required to implement the verification monitoring program as detailed in the approved DWQMP and report any non-compliance with the water quality criteria for the parameters monitored. Additionally, Seqwater must report any non-compliance with a health guideline value through monitoring or other activity that is not part of this program.</p>	<p>Compliant.</p> <p>There were three non-compliances with relevant criteria including health guideline values in the ADWG and standards in the Public Health Act as identified through the verification monitoring program.</p> <p>Reporting requirements were compliant.</p> <p>Seqwater has fully implemented its verification monitoring program, with the exception of:</p> <ul style="list-style-type: none"> - Five missed sample events at WTPs while supply was being maintained to the zone by water cartage - Three missed sample events due to North Pine WTP being offline for maintenance - Two missed sample events at the Wivenhoe Dam WTP distribution system sample point due to the sample point being inaccessible within a construction area <p>Seqwater is not aware of any other non-compliance with the health guideline values in the ADWG that could have been identified through other monitoring including research activities.</p>

Rev. no.	Doc No.	Doc Owner	Version Date	Doc Approver
01	D22/322151	Principal Water Quality	19/12/2022	Manager – Technical Support and Improvement

Condition	Compliance
No. 2. Additional Reporting requirements; (a) events and (b) where a parameter has no water quality criteria	
<p>Additional reporting requirements include:</p> <ul style="list-style-type: none"> An event including anything that has happened to Seqwater’s service which has escalated beyond its ability to control, and Seqwater believes, or is concerned, that public health may be impacted as a result. Where a parameter has no water quality criteria which Seqwater believes cannot be managed under its DWQMP and Seqwater believes, or is concerned, that public health may be impacted. <p>These reporting requirements must be made immediately to the Regulator and in the prescribed form within 24 hours.</p>	<p>Compliant.</p> <p>Seqwater has actively reported all events relating to its treatment operations which had the potential to impact on public health.</p> <p>Incident reporting included two events where there was an increased risk profile and a third event that WSR declared ‘non-reportable’ (incorrect elevated pesticide concentration in source water due to analytical error).</p> <p>Reporting requirements were compliant.</p>
No. 3. Research projects and additional reporting requirements	
<p>If Seqwater becomes involved in any water quality research activities and becomes aware of a detection that must be reported as:</p> <ul style="list-style-type: none"> Non-compliance with water quality criteria An event A parameter with no water quality criteria <p>These reporting requirements must be made immediately to the Regulator and in the prescribed form within 24 hours, unless Seqwater has obtained formal acknowledgement of the research activity by the Regulator.</p>	<p>Seqwater is not aware of any non-compliance with the health guideline values in the ADWG, events that could impact on public health, or detections of parameters without water quality criteria that is identifiable from water quality research activities.</p>
No. 4. Financial outlays	
<p>The State accepts no liability for any financial outlay incurred by you in complying with the drinking water quality management plan and the conditions in this approval.</p>	<p>No applicable claims/actions.</p>

3.2 Risk assessment

Assessment of Seqwater’s water treatment operations and supply system and eight risk assessment reviews were completed during the reporting period. There are 34 water treatment schemes listed in Section 5.1 of the Information Notice for the approved DWQMP including, 32 water treatment plants the Gold Coast Desalination Plant and the Supply System.

The findings from the recent risk assessment reviews are consistent with those reported in the 2020-21 DWQMP report (i.e. the main risks identified did not significantly change, and in most cases, pathogens are the predominant limiting hazard). From these recent reviews, significant risks and improvements to reduce those risks to acceptable levels were identified. Multiple sites have identified opportunities for:

- increased source water and raw water quality information collation to aid in decision-making to optimise source selection of raw water to the WTP

Rev. no.	Doc No.	Doc Owner	Version Date	Doc Approver
01	D22/322151	Principal Water Quality	19/12/2022	Manager – Technical Support and Improvement

- process assessment and optimisation of coagulant dosing and mixing to optimise flocculation and settling performance
- improved system monitoring and control around filter performance and supernatant management to optimise filter performance and reduce filter breakthrough probability
- improved asset integrity protective measures against animal and stormwater ingress
- improved disinfection, secondary disinfection and network monitoring of disinfectant residuals.

In some cases, the residual (mitigated) risks have been further reduced by capital upgrades to assets as part of the regular asset management process. Improvements identified through incident management processes include protection from lightning strikes and power interruptions on control systems. Improvements identified through the risk assessment review process include SCADA upgrades, process instrumentation, and interlocks between these instruments and plant operation. These improvements have reduced the risk of non-compliant water leaving WTPs.

The remaining operational WTPs yet to have SCADA upgrades have been included in the forward program schedule. Seqwater is continuing to monitor its progress in these areas through its capital works and renewals programs and the implementation of its Monitoring and Control System Asset Class Plan.

Seqwater also reviewed and improved upon the established Pre-requisite Programs (**PRPs**) and operational Pre-requisite Programs (**oPRPs**) (Enclosure 4). This approach is consistent with the requirements of AS NZS/ISO22000:2018 Food Safety Management Systems standard to which Seqwater has maintained its certification (See Section 6.2 for more details).

3.3 Operational monitoring

3.3.1 Water Treatment Plant operational monitoring

Operational monitoring in water treatment includes real-time monitoring through process instrumentation, operator grab sample tests and observations, and analytical laboratory testing by Seqwater’s process laboratories. Operational monitoring programs for each WTP are designed to assess the performance of preventive measures identified for particular hazardous events and to prompt requirements for corrective actions.

Following the recommendations in the ADWG with regards to the reliance on operational monitoring, the site-specific Hazard Analysis and Critical Control Point (**HACCP**) plans generally specify online monitoring as the Critical Limit monitoring. All potential exceedances are first verified to rule out instrumentation measurement errors, and upon verification are reported to the Drinking Water Quality team within a specified timeframe.

The main preventive measures are well established across all WTPs, with Critical Control Points (**CCP**) monitored by online instrumentation clearly identified in the process flow diagrams in each site-based HACCP Plan. Where possible, multiple levels of alarms for each online instrument through the SCADA system provide early warning of process control issues and early intervention by Operations staff. Additionally, some alarm set points are interlocked to shut down the WTP before Critical Limits are exceeded.

The HACCP Plan Wall Chart procedures document the Action Limits, Critical Limits and key corrective actions, including clear instructions for Operations staff and their supervisors on when the process is to be rated down or shut down, as well as reporting requirements. Across Seqwater’s treatment operations, the operational monitoring system has worked successfully throughout the year with many improvements implemented.

Internal auditing (Section 6) reviews the effectiveness of operational monitoring, online water quality instruments, alarm set points and the compliance with the CCP procedures. The main preventive measures typical of most WTPs are listed below with an update of the status of the preventive measure and operational monitoring.

Rev. no.	Doc No.	Doc Owner	Version Date	Doc Approver
01	D22/322151	Principal Water Quality	19/12/2022	Manager – Technical Support and Improvement

Table 3 Preventive Barriers in Water Treatment

Preventive Measure	Related Hazardous Events	Operational Monitoring	Status
Coagulation	Raw water exceeds treatment capability Coagulant dosing failures Low alkalinity Poor pH control Poor or excessive mixing Incorrect dose rates Inadequate coagulation aids	Dose water pH Chemical dosing alarms Observation checks of flocculation and sedimentation	Instrumentation for dosed water pH, including alarms, is established at all sites using aluminium sulfate (alum) as the coagulant and where pH regulation of the dosed water is in place. Additionally, the instrumentation and SCADA upgrade provides settled water turbidity analysers and alarms across all of Seqwater's sites that have a clarification or Dissolved Air Flotation process. Operator grab sample monitoring has been compliant with the WTPs HACCP plan which documents operational monitoring.
Filtration	Raw water exceeds treatment capability Coagulation failure Solids carryover Poor backwashing Filtration break-through	Online turbidity for each cell/filter outlet SCADA tools such as head loss, runtime / production For membrane filtration sites - Pressure Decay Test.	Instrumentation is in place for monitoring individual filters for filtered water turbidity at all relevant sites. All sites have alarms that automatically dial-out to the on-call operator's mobile phone. Most sites have interlocks in place to stop operation or activate filter backwash. There is a program of control system upgrades to implement this functionality across all sites where it is achievable. Online instrumentation and operator grab sample monitoring has been compliant with the WTPs HACCP plan which documents operational monitoring.
Disinfection (by Ultraviolet irradiation (UV))	High flows – low contact time Low flows – not enough turbulence to distribute the dose Low UVT – unable to adequately penetrate microorganisms	Online UV intensity and flows UV Dose Ultraviolet Transmittance (UVT)	UV disinfection is typically implemented at sites that require pathogen treatment beyond what is achievable by 'conventional treatment.' These sites include Kilcoy, Capalaba, Beaudesert, and Kalbar WTPs. It is also implemented at smaller sites, such as Dayboro, Kenilworth and Linville WTPs where it forms an efficient primary pathogen treatment process. UV disinfection has worked effectively at these sites without significant issues/excursions.

Rev. no.	Doc No.	Doc Owner	Version Date	Doc Approver
01	D22/322151	Principal Water Quality	19/12/2022	Manager – Technical Support and Improvement

Preventive Measure	Related Hazardous Events	Operational Monitoring	Status
Disinfection (by chlorination)	Chlorine dosing failures Incorrect dose rates Poor pH control High flows – low contact time Low reservoir levels Contamination to reservoir Filter break-through causing shielding	Online free chlorine after dosing and after contact time Online pH and turbidity after contact time Reservoir levels and flows Chemical dosing alarms	All sites have online instrumentation monitoring free chlorine, pH and flow in the dosed filtered water and treated water and alarms dial-out to the on-call operator’s mobile phone. At most sites, interlocks are also implemented that stop the WTP process. There is a program of control system upgrades to implement this functionality across all sites where it is achievable. Online instrumentation and operator grab sample monitoring has been compliant with the WTPs HACCP plan which documents operational monitoring.
Fluoridation	Overdosing fluoridation chemical	Online fluoride monitoring pre and post on-site reservoir Operator fluoride monitoring – concentration by lab testing Operator monitoring – daily calculated fluoride dose using product weights and flow meter data. Chemical dosing alarms	The fluoride dosing monitoring arrangements are fully established and documented. Operator testing and checks of the online monitoring system are performed at least daily. Queensland Health periodically audit fluoridation of the water supply at all Seqwater sites with fluoridation systems.
Reticulation (recreation sites)	Ingress or infiltration Corrosion and deterioration of assets	Observation Chlorine residual monitoring Demand monitoring (plant operation hours and reservoir levels) Vermin proofing inspections on reservoirs.	Reticulation systems are monitored by operational staff to ensure there is no ingress from vermin or through loss of positive pressure. System leaks are identified by these inspections and the draw on the plant’s capacity. Scheduled maintenance inspections and condition assessments are also conducted. Chlorine testing on recreation park taps is undertaken and supported by verification monitoring at the same sample sites.

Rev. no.	Doc No.	Doc Owner	Version Date	Doc Approver
01	D22/322151	Principal Water Quality	19/12/2022	Manager – Technical Support and Improvement

3.3.2 Supply System operational monitoring

In the DWQMP, operational monitoring includes the planned sequence of measurements and observations to assess and confirm the performance of preventive measures identified for particular hazardous events. Measurements of operational parameters indicate the effectiveness of processes. As part of the ADWG Framework, AS NZS/ISO22000 Food Safety Management Systems standard and HACCP standards, these operational measures have been identified and summarised within the supply system HACCP plan as CCPs and operational Pre-requisite Programs.

The preventive measures are well established within Seqwater, with CCPs monitored by online instrumentation throughout the supply system. Supply system staff can react to the exceedances when notified through the SCADA system. Alarming is programmed into the SCADA system at three different incident levels, each defining the severity of the exceedance. Each incident level has a documented contingency and escalation procedure for staff to follow.

Internal auditing and compliance spot checks monitor the operational Pre-requisite Programs. The principal preventive measures are listed in Table 4. The most common limiting hazard identified is pathogens. Unacceptable risks requiring further treatment are listed in the improvement plan (Section 4) of this report.

Table 4 Preventive Measures in the Supply System

Preventive Measure	Related Hazardous Events	Operational Monitoring	Status
Water quality considerations as part of the Monthly Operating Supply Schedule (MOSS) & routine meetings with WSPs (Regional Operational Managers Meeting). Includes drought operating modes.	Non-compliant water supplied to the Supply System by Bulk Water Suppliers Deterioration of water quality in service reservoirs due to variable water ages	This is issued monthly to the Drinking Water Quality team for review and to provide feedback on any foreseen issues arising from different source waters.	This formalised process continues as the MOSS at Seqwater. Water quality issues are raised if there are concerns of any localised issues and the MOSS amended accordingly e.g. Mt Crosby Geosmin and 2-methyl isoborneol (MIB) issues.

Rev. no.	Doc No.	Doc Owner	Version Date	Doc Approver
01	D22/322151	Principal Water Quality	19/12/2022	Manager – Technical Support and Improvement

Preventive Measure	Related Hazardous Events	Operational Monitoring	Status
Maintain disinfection residual	<p>Non-drinking water or organic matter entering service reservoir or pipeline</p> <p>Contamination to reservoirs by access by third party</p> <p>Contamination to reservoir by vermin entry</p>	<p>Chlorine, pH and temperature parameters are measured online at all Key Interface Points which is representative to each water zone. These signals are transferred and alarmed at the 24/7 operations centre. Operations centre escalation and corrective action procedures are audited routinely. Training is delivered for new operations centre staff.</p>	<p>Established SCADA systems and critical limit alarm levels notify the operations centre of low chlorine residual. Escalation procedures covering different severities of alarms are well established and are followed by operations centre staff. Corrective actions are documented in a procedure and are followed by operations centre staff and supply system operations management. A documented procedure on maintaining chlorine residual is used by operational staff.</p>
Service Reservoir Inspection Program	<p>Ingress of non-drinking water to reservoirs</p> <p>Vermin entry to reservoir</p> <p>Corrosion and deterioration of assets</p>	<p>Service reservoir inspections are carried out monthly using a checklist and photo evidence process. These records are audited routinely to identify any deficiencies. These inspections are supplemented by annual external inspections using Unmanned Aerial Vehicles (UAV), and three-yearly internal inspections using submersible Remote Operated Vehicles (ROV) combined with specialist software to inspect and track deterioration.</p>	<p>This process and water quality focused culture is well established within the business. Any issues identified are raised and corrected through the Seqwater maintenance system and for larger improvements via the renewals process within the capital improvement program.</p>
Mains Hygiene Procedure	<p>Stagnation of reservoirs and pipelines</p> <p>Commissioning new assets and pipelines</p> <p>Maintenance and operational changes to the supply system</p>	<p>This procedure provides the formal process to prevent contamination of pipelines and reservoirs during maintenance activities. It also covers disinfection of assets before returning to service. On-site compliance checks are routinely carried out to identify any deficiencies.</p>	<p>This process and water quality focused culture is now well established within Seqwater. Training is delivered during the induction of new field staff.</p>

Rev. no.	Doc No.	Doc Owner	Version Date	Doc Approver
01	D22/322151	Principal Water Quality	19/12/2022	Manager – Technical Support and Improvement

Preventive Measure	Related Hazardous Events	Operational Monitoring	Status
Locked and alarmed hatches on reservoirs	Contamination to reservoirs by access of third party	All reservoirs' hatches are locked, and alarm systems notify the 24/7 operations centre of any unauthorised access to reservoirs. Closed Circuit TV cameras are also in place at some reservoir sites. Security guards routinely patrol the reservoir sites.	The alarming of reservoirs is tested routinely with operations centre staff well versed in the procedures if a security breach occurs. Access to these reservoirs is managed by Seqwater's works access and permit to work procedures.
Maintaining Positive Pressure	Ingress of non-potable water or organic matter to pipelines	Pressure and flow are monitored online at locations throughout the supply system. These locations are alarmed and notify the 24/7 operations centre of any low-pressure situations.	The operations centre staff are well versed in the procedures to follow in the case that low pressure occurs within the supply system. Planned and unplanned pipeline isolations are managed by the Disinfection of Water Mains Procedure.
Optimisation of re-chlorination through automated control systems Maintain or treat to lower DOC/Bromide Levels	Formation of disinfection by-products	All chemical dosing facilities are comprehensively equipped with system redundancies including dual online instruments, Uninterruptable Power Supply, multiple chemical dosing pumps, back-up telemetries with multi-barrier alarming to the 24/7 operations centre.	Control systems are well established and have a proven historical track record in providing accurate and timely information. The operations centre has comprehensive documentation to assist in the control of these systems and are well versed in the procedures to operate these stations efficiently and effectively.
Pigging or super-chlorination of pipelines	High flow or changes in flow rate or direction in pipelines	Turbidity and conductivity parameters are measured online at all Key Interface Points.	Routine cleaning programs for reservoirs are in place. However, there is no routine scheduled pigging program for the existing pipelines. Biofilm testing has proven biofilms are in low volume and pathogens have not been detected in the samples measured. High flows and direction changes are managed through the control systems and operating manuals.

Rev. no.	Doc No.	Doc Owner	Version Date	Doc Approver
01	D22/322151	Principal Water Quality	19/12/2022	Manager – Technical Support and Improvement

3.4 Verification monitoring

The results of Seqwater's verification monitoring during the 2021-22 reporting period are summarised below. The detailed data report at Enclosure 1 is in the format prescribed by the Regulator. This program includes:

- the Scheme component (e.g. reticulation, source water)
- parameter
- unit of measure
- total number of samples collected (number of analyses)
- number of samples that did not meet the water quality criteria
- minimum concentration or count
- maximum concentration or count
- average (arithmetic mean) concentration or count.

For all parameters tested more than once a year, the frequency of sampling has been distributed evenly throughout the year (weekly, monthly, quarterly or six-monthly).

3.4.1 Analysis of Micro-pollutants using Passive Samplers

The sampling and analysis of micro-pollutants using a passive sampler methodology began in July 2014 for catchment sites where the sampling devices could be deployed. The micro-pollutants analysed included pesticides, pharmaceuticals and personal care products. This analysis is undertaken by a specialist laboratory under a rigorous internal quality system.

The passive sampler reports for sampling conducted during the 2021-22 reporting period are provided at Enclosure 2a and 2b. There were no exceedances of the ADWG values observed during the 2021-22 reporting period for these chemicals using passive sampling methodologies. Some parameters have been detected at trace levels, but this has generally been two orders of magnitude below the guideline values. There was a false detection of the pesticide Fipronil above the ADWG health value in the summer program at Leslie Harrison Dam (Capalaba WTP). Further investigation confirmed that the result was due to an analytical error and retesting showed that levels were below the ADWG value and the result re-issued by the laboratory. The Water Supply Regulator declared the notification as 'Non-reportable'.

3.4.2 Compliance with DWQMP and Key Performance Indicators

Drinking water quality compliance is measured using the methods recommended by the ADWG and the *Public Health Regulation 2018 (PHR)*. For corporate Key Performance Indicator (KPI) reporting, the water quality results from routine monitoring in each supply zone are assessed over a 12-month period against the water quality criteria, with the final report being issued in June each year. A supply zone is defined as a WTP and if relevant, the connected downstream components of the supply system. The methods are briefly described below:

3.4.2.1 Microbiological compliance

A supply zone is compliant if at least 98% of routinely monitored samples do not exceed the water quality criteria, namely *E. coli* (as per section 52 of the PHR).

Rev. no.	Doc No.	Doc Owner	Version Date	Doc Approver
01	D22/322151	Principal Water Quality	19/12/2022	Manager – Technical Support and Improvement

3.4.2.2 Health related compliance

For parameters sampled eight or more times during the year, the 95th percentile result of each health-related parameter is used for assessment against the water quality criteria, being the health guideline values in the ADWG as per section 52 of the PHR. For parameters sampled less than eight times per year, the maximum result is used for assessment against the water quality criteria. If the 95th percentile (or maximum if sampled less than eight times) value is greater than the water quality criteria, then the whole zone is deemed non-compliant.

3.4.2.3 Aesthetic compliance

The average of each parameter is assessed against the water quality criteria (aesthetic guideline values from the ADWG) only if there are impacts to downstream users. If any value is greater than the water quality criteria, then the whole zone is deemed non-compliant.

Seqwater was measured to be compliant during the 2021-22 reporting period for all of its water treatment operations and supply system zones for microbiological, health and aesthetic compliance.

3.4.3 Water Treatment Plant verification monitoring

Verification monitoring occurred in accordance with Seqwater's Water Quality Verification Monitoring Plan. This was primarily undertaken by the NATA-accredited (ISO 17025) contracted Laboratory Service Provider at Seqwater's raw water, treated water and recreation sites distribution system sample points, covering more than 70 different parameters at various frequencies. On-site field testing and monitoring supports operations, but also forms part of the verification monitoring program, such as Taste and Odour compounds, is undertaken by Seqwater in accordance with its laboratory quality management system, based on ISO 17025. The verification program provides the necessary information to validate the preventive approach to water quality management is effective.

A summary table of verification monitoring of the treated or supply system (bulk) water for the Reporting Period is provided in Table 5. The statistics from the verification monitoring results for all parameters for raw water and treated water at each operational site is provided within Enclosure 1. The recreational plants show a larger number of analyses performed as these sites include reticulation system monitoring in WTP test count.

Table 5: WTP Verification Monitoring Summary

Name of scheme component	Number of Analyses Performed	Number of Individual ADWG Health Exceedances	Number of Individual ADWG Aesthetic Exceedances
Amity Point WTP	759	0	0
Beaudesert WTP	864	0	0
Banksia Beach WTP	0	0	0
Boonah-Kalbar WTP	866	0	0
Canungra WTP	908	0	0
Capalaba WTP	866	0	0
Dayboro WTP	756	0	0
Dunwich WTP	775	0	0
Esk WTP	826	0	0
Ewen Maddock WTP	866	1	0

Rev. no.	Doc No.	Doc Owner	Version Date	Doc Approver
01	D22/322151	Principal Water Quality	19/12/2022	Manager – Technical Support and Improvement

Name of scheme component	Number of Analyses Performed	Number of Individual ADWG Health Exceedances	Number of Individual ADWG Aesthetic Exceedances
Hinze Dam WTP	1185	0	0
Image Flat WTP	1776	0	0
Jimna WTP	856	0	0
Kenilworth WTP	759	0	0
Kilcoy WTP	872	0	0
Kirkleagh WTP	1188	0	0
Kooralbyn WTP	826	0	0
Landers Shute WTP	881	0	0
Linville WTP	1216	1	5
Lowood WTP	855	0	0
Maroon Dam WTP	1156	0	0
Molendinar WTP	869	0	0
Moogerah Dam WTP	1147	0	0
Mt Crosby East Bank and West Bank WTPs	1786	0	0
Mudgeeraba WTP	861	0	0
Noosa WTP	1438	0	0
North Pine WTP	932	0	1
North Stradbroke Island WTP	816	0	0
Point Lookout WTP	756	0	0
Rathdowney WTP	816	0	0
Somerset Dam WTP	872	0	0
Tugun Desalination Plant	1516	0	0
Wivenhoe Dam WTP	1551	0	0
Total	32416	2	6

During the reporting period a total of ten sample events were missed:

- Five occurred when WTPs were offline due to wet weather with the zones supplied via water cartage
- Three occurred at the North Pine WTP, when it was offline for planned maintenance, with the reservoir drained. It was not possible to take samples of treated water.
- Two in the Wivenhoe WTP distribution system, due to the sample point being located within a construction zone and inaccessible to the sampler.

Rev. no.	Doc No.	Doc Owner	Version Date	Doc Approver
01	D22/322151	Principal Water Quality	19/12/2022	Manager – Technical Support and Improvement

3.4.4 Analysis of the Water Treatment Plant verification monitoring data

Through an assessment of the water quality data from the verification program, it was found WTPs were compliant against the ADWG health guideline values for drinking water. Two health exceedances recorded during the reporting period were investigated and found to be related to contamination during the sampling-analysis processes. This exemplifies the continued improvement Seqwater has shown in driving excellence in our drinking water quality management.

Overall, the count of ADWG health-related exceedances over the past few years has remained at a relatively constant low level with no exceedances occurring in 2018-19 and 2020-21, which is a considerable achievement given the number of diverse schemes and systems. The increase in the number of aesthetic exceedances in 2021-22 has been mainly due to increased treated water hardness levels at Linville WTP, otherwise exceedances have, on average, been generally decreasing (Figure 1). The continued improvement in reducing exceedances across all WTPs is evident in the simple linear trend of total exceedances.

The two ADWG health exceedances (*E.coli* detections with 80 MPN/100 mL detected at Ewen Maddock WTP and 7 MPN/100 mL detected at Linville WTP, 24/3/2022) were attributed to sampling undertaken on the same day across two sample runs in the northern operations region. A third *E. coli* detection occurred in the Supply System on the same day (refer section 3.4.6). Chlorine disinfection residuals were present in the treated water at each location and there were no operational issues. This indicated that the issue related to contamination at a point during the process of sample bottle preparation, sampling, sample transport or laboratory testing. The investigation was unable to identify the exact point at which the sample was compromised. These results were reported to the Regulator within the required timeframes.

The six aesthetic guideline exceedances in the routine verification monitoring included:

1. one elevated pH result in the treated water from North Pine WTP (pH 8.9, 26/4/2022). There was a higher variation in pH control at the WTP around the time of the result due to challenging post-flood source water conditions where alkalinity was very low and required higher lime dosing rates which strained the pH control systems
2. five elevated hardness results in the treated water from Linville WTP (270-350 mg/L, 13/4/2022 – 29/4/2022). These are due to an increase in source water hardness levels, following the period of significant wet weather. The WTP is not able to remove hardness, however, improvement to the WTP’s ability to reduce hardness is progressing through Seqwater planning processes.




Figure 1 WTP exceedances over different reporting periods

Rev. no.	Doc No.	Doc Owner	Version Date	Doc Approver
01	D22/322151	Principal Water Quality	19/12/2022	Manager – Technical Support and Improvement

Seqwater continues to seek and implement improvements for its treatment processes and preventive measures. With regards to continually improving water quality (for example, in accordance with Element 12 of the Framework for Management of Drinking Water Quality), these exceedances are considered in risk assessments and subsequent risk assessment reviews. Where a mitigated risk has been determined to be inadequate, even for aesthetic parameters, an improvement action is recorded in the DWQ Improvement Plan (Enclosure 3). Subsequent processes ensures those improvement actions are addressed appropriately. This currently includes treatment plant upgrades, improved instrumentation, early intervention by operations and engineering staff through changes in process control and improvements in sampling practices and the third-party NATA-laboratory performance.

3.4.5 Supply System verification monitoring

Verification monitoring occurred in accordance with the Supply System Water Quality Monitoring Plan. Sampling and on-site field tests were undertaken by Seqwater’s field services team and laboratory testing was undertaken by a contracted NATA-accredited laboratory service provider. This covered more than 30 different parameters with weekly and monthly sampling frequency scheduled in eight different zones. The verification program provides the necessary information to validate the preventative approach to water quality management is working effectively.

The Supply System has been assessed as compliant for all eight zones for microbiological, health and aesthetic compliance during the reporting period, as shown in Table 6.

Table 6 Supply system verification monitoring summary.

Name of scheme component	Number of Analyses Performed	Number of Individual ADWG Health Exceedances	Number of Individual ADWG Aesthetic Exceedances
Brisbane	21515	0	3
Eastern Pipeline Interconnector (EPI)	2363	0	0
Gold Coast and Network Integration Pipeline (NIP)	3926	0	0
Logan	3725	0	0
Northern Pipeline Interconnector (NPI)	10301	1	0
Redland	5596	0	0
Southern Regional Pipeline (SRP)	11120	0	0
Total	58546	1	3

3.4.6 Analysis of the Supply System verification monitoring data

There was one ADWG health exceedance and three aesthetic guideline exceedances for the Supply System during the reporting period consistent with the low numbers of exceedances for each category since 2014-15 reporting period (Figure 2). Although the initial drop in 2013-14 may be attributed to the reduction in monitoring when a risk-based approach was adopted, the overall trend supports the continued successful operation of the Supply System to provide safe and high-quality drinking water.

The ADWG health exceedance (*E.coli* detection at Nambour offtake on the NPI, 24/3/2022) was related to issues with the same northern operations sample run described above in section 3.4.4 where two WTP samples

Rev. no.	Doc No.	Doc Owner	Version Date	Doc Approver
01	D22/322151	Principal Water Quality	19/12/2022	Manager – Technical Support and Improvement

were also affected by contamination during bottle preparation, sampling, transport or analysis processes. This result was reported to the Regulator within the required timeframes. An elevated Total chlorine result was reported for Noosa WQMF on the NPI (5.4 mg/L, 14/3/2022), however, this result was due to an unrepresentative sample that had been collected whilst the WQMF was offline (no water supplied). There were no corresponding elevated chlorine concentrations detected in Supply System or distribution network downstream of the WQMF.

The three aesthetic exceedances included an elevated pH result (pH 9.0, 5/5/2022) and two elevated ammonia results (0.60 mg/L, 5/5/2022 and 0.47 mg/L, 30/5/2022) at Aspley WQMF. The results from the Aspley WQMF were not consistent with upstream and downstream monitoring results and were found to be due to issues with sample tap configuration that has the potential to affect collection of a representative sample. Replacement sample taps that meet Seqwater’s engineering standards are planned to be installed at this site.




Figure 2 Supply System exceedances over different reporting periods

The minimal number of exceedances across the Supply System since 2014-15 is supported by good operating practice. Improved source water conditions also contributed to a strong performance in some of the previous reporting periods, but there have been more challenges for water treatment and distribution during the current reporting period (2021-22) due to increased heavy rain events.

Rev. no.	Doc No.	Doc Owner	Version Date	Doc Approver
01	D22/322151	Principal Water Quality	19/12/2022	Manager – Technical Support and Improvement

4 Improvement plan

Improvements continue in accordance with the DWQIP. The progress made during the reporting period to reduce health-related risks and improve the reliable provision of safe drinking water is tabled in Enclosure 3 of this report. Any improvements which are yet to be implemented are reassessed and prioritised through the internal audit and risk assessment review schedule. Asset-related improvements are assessed via the capital program prioritisation process. The changes to the DWQMP identified in risk assessment reviews, HACCP team meetings and the investigation of incidents, reflect the significant amount of progress Seqwater has made in improving its drinking water quality management system. The details of these changes are provided in the register of changes to DWQMP, HACCP plans and procedures at Enclosure 4. A summary of significant water quality improvement deliverables in the reporting period are listed below.

Whole of Business:

- Review of management system against ISO 22000:2018 in preparation for certification audit.
- Implementation of process engineering assessments and audits.
- Improvement opportunities for online analyser maintenance.
- Implementation of consistent reservoir inspection program.
- Improvements to pest management program.
- Implementation and ongoing improvement of a pre-requisite program (PRP) for food defence, biovigilance and bioterrorism.
- Improved and re-negotiated water quality parameters under our Bulk Water Supply Agreements (**BWSA**) with our WSPs – amended BWSAs were agreed with City of Gold Coast, City of Logan, Redland City Council and Urban Utilities during the 2021-22 reporting period.
- Implementation of a new laboratory information management system called LabWare provided enhanced data management and reporting functions.

Northern Region:

- SCADA and communication improvements including interlocks and process control for filtration and disinfection.
- Jimna WTP reservoir upgraded with an aeration system to reduce Total trihalomethanes (THM) levels.
- Landers Shute WTP and Ewen Maddock WTP implemented polymer dosing systems for coagulation and flocculation in response to challenging source water conditions from impacts of heavy rain events.

Central Region:

- East Bank WTP Stage 2 Filter upgrade including media replacement and increased dual media filter depth was completed in April 2022.
- East Bank WTP SCADA upgrades commenced including movement of filtration and some chemical dosing onto the new system.
- Mt Crosby Cameron's Hill Reservoirs chloramination dosing system upgraded to include static mixers to improving mixing at lower flow rates.
- Re-chloramination upgrade at Aspley WQMF to allow dosing in southern flow direction.
- Construction has commenced on South West Pipeline to connect Beaudesert to the Water Grid by 2023.

Rev. no.	Doc No.	Doc Owner	Version Date	Doc Approver
01	D22/322151	Principal Water Quality	19/12/2022	Manager – Technical Support and Improvement

Southern Region:

- Planning has commenced with approval to install UV-disinfection at Kooralbyn and Rathdowney WTPs to improve treatment capability by 2024.
- Improved understanding of ground water quality risks on Minjerribah (North Stradbroke Island) – Ground water infiltration zone report to inform water quality risk, potential ground water protection zones and development assessment.
- Point Lookout WTP re-establishment of Bore 1 due to the poor asset condition of the existing bore.

Rev. no.	Doc No.	Doc Owner	Version Date	Doc Approver
01	D22/322151	Principal Water Quality	19/12/2022	Manager – Technical Support and Improvement

5 Drinking water quality incidents

The following section summarises information given to the Regulator detailing:

- Non-compliances with the water quality criteria for drinking water, and the corrective and preventive actions undertaken in response
- Prescribed incidents reported during the year including corrective and preventive actions
- Comments on the effectiveness of any preventive/control measures.

A summary of incidents at Seqwater’s treatment operations and Supply System reportable to the Regulator are shown in Table 7. Seqwater had two incidents considered ‘reportable events’ and another considered by the Regulator as ‘non-reportable’. Reporting to the Water Supply Regulator was completed within the required timeframes.

Table 7 A summary of incidents at Seqwater’s treatment operations and Supply System

Incident Number	Name of scheme component	Date Reported	Description of the Event/Incident	Improvements
DWI-507-22-09570	Wivenhoe WTP	15/04/2022	<p>Event: During routine daily site attendance on 15/04/2022 at about 7am the Operator identified that filtered water turbidity had risen above the critical limit, however, the interlock had not tripped to shut down the WTP. The Operator manually shutdown the WTP. It was confirmed that Lumley Hill reservoir did not take water during this time, water only flowed to the Cormorant Bay zone. Verification monitoring through follow up samples collected on 17-18 April 2022 had no <i>E.coli</i> detected.</p> <p>The two on-site reservoirs (treated water tank and high-level reservoir) were drained. Lumley Hill supply zone isolated. Do not drink signs were installed in the public areas of the Cormorant Bay supply zone and Seqwater staff and residents advised to not drink the water. Drinking water was carted into treated water reservoirs and the Cormorant Bay distribution system flushed.</p>	Drinking water is continuing to be carted by water tanker to maintain supply while future options for supply to the Wivenhoe Dam recreation area are investigated.

Rev. no.	Doc No.	Doc Owner	Version Date	Doc Approver
01	D22/322151	Principal Water Quality	19/12/2022	Manager – Technical Support and Improvement

Incident Number	Name of scheme component	Date Reported	Description of the Event/Incident	Improvements
DWI-507-22-09603	Kimberley Park Reservoir	10/05/2022	<p>Event: Level instrumentation at Kimberley Park Break of Head (BoH) tank failed resulting in an overflow of approx. 2.3ML on 6 May 2022. The Daisy Hill treated water pump station supplying water to the tank was stopped as soon as the issue was identified. The BoH tank sits underneath the pump station in the same building. The tank overflow was unable to cope with volume of water and as a result, water flooded the pump station above and an estimated 500 L could have re-entered the Break of Head tank. The possibility of contamination issue was not identified until 10 May 2022 during an investigation.</p> <p>The BoH tank can pump water into the Kimberley Park Reservoir (owned by Seqwater) or the City of Logan distribution network. At the time of the incident, total chlorine levels were 0.1 mg/L due to system conditions such as water age and temperature. Sampling for microbial testing was undertaken on 10-11 May (3 sets) and the results indicated no evidence of microbial contamination.</p>	<p>The root cause was identified as the failure of the level indicator for the BoH tank due to a water leak from Treated Water Pump No.3.</p> <p>The pump was isolated until repaired.</p> <p>The investigation identified additional improvements that are progressing through Seqwater's planning processes.</p>
DWI-507-22-09632	Capalaba WTP – Leslie Harrison Dam	07/06/2022	<p>Event: A pesticide detection (Fipronil) in source water that was above the ADWG health value was notified to the Water Supply Regulator as an ADWG Health exceedance, as monitoring is not undertaken in the treated water verification monitoring program. Further investigation found the result was due to an analytical error. The Water Supply Regulator indicated the initial notification should have been reported as an Event and subsequently determined the event was 'Non-reportable'.</p>	Non-reportable Event

Rev. no.	Doc No.	Doc Owner	Version Date	Doc Approver
01	D22/322151	Principal Water Quality	19/12/2022	Manager – Technical Support and Improvement

6 Audit of the Plans

6.1 Regular audits

Seqwater must audit its DWQMP at the intervals stated in an Information Notice provided under section 99 of the Act. The Information Notice for the approval of Seqwater's amended DWQMP dated 15 March 2021 specifies the next regular audit of the DWQMP is to be completed by 1 March 2025. Further regular audits are required to be completed every five years from that date. Accordingly, there was no regular audit of the DWQMP during the 2021-22 reporting period.

6.2 Audits – water treatment and Supply System operations

6.2.1 Internal audits – HACCP and Integrated Management System audits

Internal audits have been conducted throughout the year in accordance with Seqwater's HACCP and Integrated Management System audit schedules. The scope of the internal audits includes the relevant site's HACCP plan, wall chart procedure (incorporating the CCPs), operational monitoring plan, and operator and maintenance records. It includes verification of the HACCP flow diagram and process flow schematic by the HACCP Team Leader and available operational staff from the HACCP team. Internal audits have been conducted at 17 WTP and Supply System sites in the reporting period. COVID restrictions limited site access for the internal audit program and reduced the number of audits conducted (down from 21 internal audits in the previous year) and some audits were conducted remotely during 2021. Seqwater's remaining operational sites are scheduled as part of an ongoing audit cycle.

All major and minor non-conformances and opportunities for improvement are delivered through engagement with operations staff and the use of Seqwater's electronic document and record management systems. There were 22 HACCP team meetings conducted across Seqwater's operation regions during the reporting period.

6.2.2 External audits – AS NZS/ISO 22000 Re-certification audits

Seqwater has integrated the AS NZS/ISO22000:2018 Food Safety Management Systems standard into the DWQMP. Many of the requirements of the standard are consistent with, or similar to, the elements in the DWQMP, which is based on the ADWG Framework. This standard promotes greater commitment from all parts of the business during DWQMP implementation and ensures the DWQMP becomes part of the Integrated Management System (**IMS**).

During the reporting period, Seqwater prepared for re-certification against AS NZS/ISO 22000:2018 and successfully completed a certification surveillance audit conducted by its contracted third-party independent auditor. The scope of certification continues to include Seqwater's DWQMP and its major operational sites including Mt Crosby East Bank and West Bank, Capalaba, North Stradbroke Island, Molendinar, Mudgeeraba, Landers Shute, North Pine, Noosa, Image Flat, Kalbar and Lowood WTPs, and the Supply System (i.e. control room and all operational sites).

6.2.3 External audits – Regulated Fluoridation Systems audits

Seqwater participates in regulatory fluoride audits every two years. Every plant with fluoride dosing is checked for compliance with the current *Fluoride Code of Practice* by the Health Regulator (the respective Public Health Unit (**PHU**)) for the relevant WTP. The formal reporting of the audits conducted during 2021-22 reported there were no non-conformances at the following WTPs: Molendinar, Mudgeeraba, Canungra, Capalaba, North Stradbroke Island, Dunwich, Amity Point, Point Lookout, Beaudesert, Kooralbyn, North Pine, Dayboro, Kilcoy, Lowood, Esk and Boonah-Kalbar WTPs, and the Gold Coast Desalination Plant.

Rev. no.	Doc No.	Doc Owner	Version Date	Doc Approver
01	D22/322151	Principal Water Quality	19/12/2022	Manager – Technical Support and Improvement

The remaining WTPs are expected to be audited by the West Moreton and Sunshine Coast Public Health Unit during the 2022-23 reporting period.

Rev. no.	Doc No.	Doc Owner	Version Date	Doc Approver
01	D22/322151	Principal Water Quality	19/12/2022	Manager – Technical Support and Improvement

7 Regular review of the plan

Pursuant to section 10.1 of the Information Notice for the approval of Seqwater's DWQMP, Seqwater is required to complete the next review of its DWQMP before 1 July 2023. Accordingly, no regular review of the plan was conducted during the 2021-22 reporting period.

Rev. no.	Doc No.	Doc Owner	Version Date	Doc Approver
01	D22/322151	Principal Water Quality	19/12/2022	Manager – Technical Support and Improvement

8 Glossary

Term	Definition
ADWG	Australian Drinking Water Guidelines 2011, National Health and Medical Research Council, Commonwealth Government of Australia, Canberra
Alum	Aluminium Sulfate
BWSA	Bulk Water Supply Agreement
CCP	Critical Control Point
DWQ	Drinking Water Quality
DWQIP	Drinking Water Quality Improvement Plan
DWQMP	Drinking Water Quality Management Plan
EPI	Eastern Pipeline Inter-connector
HACCP	Hazard Analysis Critical Control Point. A food safety management system based on a set of guiding principles, known as HACCP Principles or Codex Alimentarius.
IMS	Integrated Management System – the combination of the certified ISO9001, ISO14001, ISO 22000 and ISO4500 systems implemented by Seqwater
ISO 22000	ISO 22000:2018 Food Safety Management Systems. International standard for food safety.
KPI	Key Performance Indicator
LIMS	Laboratory Information Management System
MIB	2-methyl isoborneol
MOSS	Monthly Operating Supply Schedule
NATA	National Association of Testing Authorities
NPI	Northern Pipeline Inter-connector
OPRP	Operational Pre-requisite program
PHR	<i>Public Health Regulation 2018 (Qld)</i>
PHU	Public Health Unit
PRP	Pre-requisite program – terminology from ISO22000:2018 (section 8.2) that refers to programs that facilitate the prevention and/or reduction of contaminants (including food safety hazards) in the products, product processing and work environment.
Regular audit	Means an audit conducted in accordance with section 99(2)(c) of the Act.
Regular review	Means a review conducted in accordance with section 99(2)(b) of the Act.
REX	Seqwater's Document and Records Management System
Seqwater	Queensland Bulk Water Supply Authority

Rev. no.	Doc No.	Doc Owner	Version Date	Doc Approver
01	D22/322151	Principal Water Quality	19/12/2022	Manager – Technical Support and Improvement

SCADA	Supervisory Communication and Data Acquisition (SCADA) system. Human to Process software interface.
SPID	Service Provide Identification – issued by water supply regulation
Supply System	Previously named the Bulk Distribution Network and formerly operated by LinkWater.
The Act	<i>Water Supply (Safety and Reliability) Act 2008 (Qld)</i>
The Regulator	The chief executive of the department is the regulator under the Act. (i.e. Water Supply Regulation – Department of Regional Development, Manufacturing and Water)
UAV	Unmanned Aerial Vehicle
UV	Ultraviolet
UVT	Ultraviolet Transmission
WQMF	Water Quality Management Facility
WSPs	Water Service Providers (Urban Utilities, Unitywater, City of Logan, Redland City Council and City of Gold Coast)
WSR	Water Supply Regulation – Department of Regional Development, Manufacturing and Water
WTP	Water Treatment Plant

Rev. no.	Doc No.	Doc Owner	Version Date	Doc Approver
01	D22/322151	Principal Water Quality	19/12/2022	Manager – Technical Support and Improvement

9 Enclosures

Enclosure	Name
1	Verification monitoring 2021-2022 Water Quality data report (REX ID: D22/322152)
2a	Catchment and Drinking Water Quality Micropollutant Monitoring Program - QAEHS Passive Sampling Winter 2021 Report (REX ID: D22/322153)
2b	Catchment and Drinking Water Quality Micropollutant Monitoring Program - QAEHS Passive Sampling Summer 2022 Report (REX ID: D22/322154)
3	Drinking Water Quality Improvement Plan (DWQIP) (REX ID: D22/322155)
4	Register of changes to DWQMP, HACCP plans and procedures - 2021-2221 (REX ID: D22/322156)

Rev. no.	Doc No.	Doc Owner	Version Date	Doc Approver
01	D22/322151	Principal Water Quality	19/12/2022	Manager – Technical Support and Improvement